**SEPTEMBER 11, 2023** 

# Burlington to Nanticoke Regional Electricity Planning

# Engagement Webinar #1



# Agenda

- 1. Ontario's Electricity Sector and IESO's Role
- 2. Burlington to Nanticoke Region Electricity Planning
- 3. Preliminary Electricity Demand Forecast
- 4. Community Engagement and Next Steps
- 5. Discussion





#### We work with:



# Seeking Input

As you listen today, consider any additional factors for:

#### Determining the electricity demand forecast for your region

- What key developments, projects or initiatives should be considered? What other information should be taken into account that would influence the forecast?

#### Identifying needs to be addressed

– What areas of concern or interest about electricity should be considered as part of the planning process?

#### Engaging with communities and interested parties

- What information is important to provide throughout the engagement?
- Does the proposed Engagement Plan provide sufficient scope and opportunities for input? What other engagement activities or methods should be considered?

#### Please submit your written comments by email to <a href="mailto:engagement@ieso.ca">engagement@ieso.ca</a> by October 2



## Burlington to Nanticoke Regional Electricity Planning



# **Electricity Planning in Ontario**



Addresses provincial electricity system needs and policy directions.

<u>Underway</u>: <u>Central-West</u> <u>Bulk Plan</u>.



Regional Planning

Addresses local electricity system needs at the transmission system level.

<u>Underway</u>: Burlington to Nanticoke Regional Electricity Plan.



Addresses local electricity system needs and priorities at the distribution system level.

Led by local distribution companies.



## **Regional Electricity Planning**

The regional system planning process ensures an affordable and reliable supply of electricity across Ontario. The process looks at the unique needs of each region, and considers a range of options and resources to keep the lights on.

A Technical Working Group, led by the IESO, and consisting of the local distribution companies and the transmitter, works together to develop a plan to address the electricity needs of each region.




Connecting Today. Powering Tomorrow.

# Burlington to Nanticoke Region

Area is divided into 4 electrical subregions, and serviced by 230 kilovolt (kV) and 115 kV lines and transformer stations (TS).

The region encompasses a number of municipalities, Indigenous communities and Métis councils from Haldimand County and Norfolk County going north towards the City of Burlington.

Integrated Regional Resource Plan (IRRP) will be developed for Hamilton, Brant and Caledonia-Norfolk sub-regions.









\*These timelines may be subject to change



9

## Components of an IRRP

| Demand Forecast   | Needs   | Potential Solutions  | Recommendations   |
|---|---|--|---|
| How much power is<br>needed over the<br>planning timeframe? | What needs are<br>emerging in the region<br>that need to be<br>addressed? | What kinds of<br>solutions can meet the<br>future needs for the<br>region? | Based on an<br>assessment of<br>potential options, what<br>recommended actions<br>will ensure a reliable<br>and adequate<br>electricity supply for<br>the region over the<br>long-term? |



## **Preliminary Electricity Demand Forecast**



# Local Planning Drivers

### Important considerations that influence the load forecast:



Municipal/regional growth plans



Climate change action plans



Community energy plans



Business plans of major electricity consumers or large projects



Local Generation/Energy Projects

Local Distribution Companies incorporate these drivers into the electricity demand forecast.



## Data Gathering – Demand Forecast

The region's needs are assessed based on a 20-year forecast of peak electricity demand. The peak demand forecast is created by:

- **1. Collecting** gross demand forecast information from local distribution companies, and assuming median weather conditions (demand is weather-sensitive).
- 2. Estimating impact of conservation and demand management targets.
- **3. Calculating** the forecast peak demand contribution of contracted distributed generation.
- 4. Adjusting the forecast to account for extreme weather conditions.




## **Preliminary Gross Forecast**

Gross forecast is based on information from distributors and transmission-connected loads about demand growth such as new residential and commercial developments and electrification projects.

#### Key takeaway:

- On average, an annual growth of 3%, 4% & 5% is expected for the Hamilton, Brant & Caledonia-Norfolk electrical sub-regions, respectively.
- Industrial electrification projects contribute to the increase in the Hamilton and Caledonia-Norfolk demand forecast.






## Generation and Conservation Considerations

In order to develop the net forecast, Distributed Generation (DG) and Conservation and Demand Management (CDM) are considered.

DG refers to small-scale generation located within a community.

CDM programs help consumers reduce electricity use.

Both measures can reduce the amount of electricity the system needs to provide.






## **Preliminary Net Forecast**

Net forecast is created by layering the impacts of conservation and demand management (CDM), distributed generation (DG), and extreme weather conditions into the gross forecast.

### Key takeaway:

- Impact of DG and CDM is less than 10%.
- The average growth rate does not change much from gross to net forecast.





# **Identifying Needs**

Once the electricity demand forecast has been created, the IESO conducts an assessment to determine needs. Generally, needs studied in this process fall under the following categories:

- **Station capacity:** Ability of a station to deliver power from the grid down to the distribution systems.
- **Supply capacity:** Ability of the system to supply power through the transmission lines to a local area.
- Asset replacement: Station or transmission equipment has reached end of life.
- Load restoration: Ability of the system to restore power after select contingencies.
- Load supply security: Maximum amount of power that can be lost during select contingencies.



# **Preliminary Identified Needs**

| Туре                 | Description   | Locations  |
|----------------------|---|--|
| Station Capacity     | Ability of station to deliver<br>power from the grid down to<br>the distribution systems. | Three stations within Caledonia-<br>Norfolk, and two stations within<br>Hamilton |
| System Capacity      | Ability of the system to supply power through the transmission lines.                     | Within Brant electrical area   |
| Asset<br>Replacement | Station equipment has<br>reached end of life.   | One station within Hamilton  |

Preliminary identified needs could be further refined, and new needs identified, as part of the detailed forecasting and evaluations.



## **Engagement and Next Steps**



# **Ongoing Engagement**

### Your input plays an important role in developing the electricity plan.



Participate in upcoming public webinars



**Subscribe** to receive updates on the IESO <u>website</u> -> select Burlington to Nanticoke Region



Follow the Burlington to Nanticoke regional planning activities online



# Key Areas for Input in Plan Development

| Milestone   | Timeline          | Community Input   |
|---|-------------------|---|
| Electricity demand<br>forecast and<br>Engagement Plan | September<br>2023 | What economic development or other growth or<br>project plans might influence the regional load<br>forecast? What additional information should be<br>considered?                         |
| Electricity needs<br>and potential<br>options         | Q4 2023           | What additional information should be considered in<br>the study assumptions? What community feedback<br>is there to the potential solutions? What other<br>options should be considered? |
| Options analysis<br>and draft<br>recommendations      | Q1 2024           | What community feedback is there on the draft<br>recommendations? What information should be<br>considered in the recommendations?  |
| Final IRRP  | Q2 2024           |   |



# Who Should Participate in the Engagement Process?

- Municipalities
- Indigenous communities and Métis councils
- Communities, including community groups and associations, and general public
- Chambers of Commerce/Boards of Trade
- Large energy users
- Academia and research organizations
- Energy service providers
- Environmental and sustainability organizations



## What we Heard so Far

Early outreach conducted with certain community stakeholders to understand issues and trends related to economic development and local energy solutions.

### Key themes emerged:



Organic growth and economic development projects across the region



Significant community energy initiatives are planned



Strong industrial growth and interest in ensuring electricity infrastructure can accommodate economic development



Interest in new generation and leveraging existing local generation



## We Want to Hear from you

### Determining the electricity demand forecast for your region

– What key developments, projects or initiatives should be considered? What other information should be taken into account that would influence the forecast?

### Identifying needs to be addressed

– What areas of concern or interest about electricity should be considered as part of the planning process?

### Engaging with communities and interested parties

- What information is important to provide throughout the engagement?
- Does the proposed Engagement Plan provide sufficient scope and opportunities for input? What other engagement activities or methods should be considered?

### Please submit your written comments by email to <u>engagement@ieso.ca</u> by October 2



## Next Steps

- Written feedback on draft electricity demand forecast and Engagement Plan due October 2, 2023
- Final engagement plan and responses to written feedback posted
- Additional engagement opportunities will be hosted at key milestones



# Appendix



# **Technical Working Group**

Team Lead, System Operator

Lead Transmitter


Local - Distribution Companies • Independent Electricity System Operator

• Hydro One Networks Inc. (Transmission)

- Oakville Hydro Electricity Distribution Inc.
- Burlington Hydro Inc.
- GrandBridge Energy Inc.
- Alectra Utilities Corporation
- Hydro One Networks Inc. (Distribution)



## Determining the Need for an IRRP





# Previous Cycles of Regional Planning

Two cycles of planning have been completed for the Burlington to Nanticoke region:

- First cycle focused on the <u>Brant</u> and <u>Bronte</u> sub-regions and completed in April 2015 and June 2016 respectively
- Second cycle focused on the <u>Hamilton</u> sub-region and completed in February 2019



# **Categories of Needs**

#### Capacity Needs

- Station capacity refers to the ability to convert power from the transmission system down to distribution system voltages
- System capacity (or "load meeting capability") refers to the ability of the electricity system to supply
  power to customers in the area, either by generating the power locally, or bringing it in through the
  transmission system

#### End-of-Life Asset Replacement Needs

- Based on the best available asset condition information at the time
- Evaluated to decide if the facility should be replaced "like-for-like", "right-sized", or retired

#### Load Restoration and Supply Security Needs

- Load restoration describes the electricity system's ability to restore power to those affected by a major transmission outage within reasonable timeframes
- Supply security describes the total amount of load interrupted following major transmission outages



## Preliminary Needs in Burlington to Nanticoke Region

|   | Need                            | Sub-region            | Need Type               | Description   |
|---|---------------------------------|-----------------------|-------------------------|---|
| 1 | Norfolk TS and<br>Bloomsburg DS | Caledonia-<br>Norfolk | Station Capacity        | Forecasted to exceed its supply capacity in 2030 and 2025<br>respectively. Currently planned to be addressed through load<br>transfers to upgraded Jarvis TS and new feeder connections in the<br>2027-2032 timeframe |
| 2 | Caledonia TS                    | Caledonia-<br>Norfolk | Station Capacity        | Forecasted to exceed its supply capacity by 2030  |
| 3 | Brant Area<br>Supply            | Brant                 | Line/System<br>capacity | The 115 kV system that supplies the Brant area (Brant TS and Powerline MTS) has a LMC of 165 MW. This LMC may be exceeded by 2032   |
| 4 | Nebo TS                         | Hamilton              | Station Capacity        | Load at T3/T\$ 230/13.8 kV DESN at Nebo TS is forecasted to exceed its supply capacity by 2032  |
| 5 | Mohawk TS                       | Hamilton              | Station Capacity        | Forecasted to exceed supply capacity by 2024  |
| 6 | Newton TS                       | Hamilton              | Asset end-of-life       | 115 kV breakers at Newton TS need to be replaced  |

