

IESO Engagement

From: Jessie Cheng
Sent: September 29, 2017 2:29 PM
To: IESO Engagement
Subject: feedback from September 12, 2017 DR stakeholder meeting

Hi,

The comments below refer to slide #17 and slide #18 with same title " Considerations for Changes" :

1. Toronto Water is maximizing its operational flexibility to participate in DR while treating and delivering water. We disagree with eliminating the standby notice which is currently issued by 7 am. As discussed at the September 12 meeting, the standby notice gives us the necessary time to plan and re-adjust pumping pattern across the City in order to fulfill our DR commitment to reduce electrical demand across a large and scattered system. We believe other large scale operations may take the same approach in order to maintain their operation integrity while contributing to DR.

2. Further to the above, we also think maintaining the current 2.5 hr prior activation notice gives us the time required to:

1. manage changes that occur within our operation after standby notice is received and
2. implement the planned DR activity whether it is in form of curtailment or generation

Jessie Cheng P.Eng.,CEM.,M.Eng.
Senior Engineer, Energy Management
Toronto Water
55 John Street, 18th Floor
Toronto, M5V 3C6