

IESO Engagement

From: Bill Greenway
Sent: March 31, 2022 2:39 PM
To: IESO Engagement
Cc: Tory Delaurier; CAO - Osei Bosompem; Kim Lauzon
Subject: Northeast Ontario IRRP Feedback

Hello,

We have a 120 MW gas-fired co-gen plant in Iroquois Falls. The pipeline contractor is currently working on increasing the natural gas capacity of this plant to 150 MW. When this improvement is implemented it means that at least 28 MW of this generation will be stranded due to the 127 MW capacity of the 115 KV radial line that originates from the plant. What 115 KV upgrades can be expected to make sure all generation and load will be accommodated? Is there anything that could be done to twin it or increase capacity to 230 KV iwhtint he scope of this IRRP?

Bill Greenway

Economic Development Officer
Town of Iroquois Falls

