

# Feedback Form

## Electricity Planning in the West of London Area – November 26, 2020

### Feedback Provided by:

Name: Jim Brown

Title: VP Hydro Operations

Organization: ENWIN Utilities Ltd.

Email: [REDACTED]

Date: 2020-12-04

### Windsor-Essex Integrated Regional Resource Plan Addendum Study

**Topic: Conversion of 115 kV infrastructure to 230 kV**

**Feedback**

What feedback do you have regarding any of the options proposed?

ENWIN and its customers have a number of transformer stations attached to the 115 kV infrastructure of Hydro One in Windsor. On a number of occasions, the station circuit switchers on the 115 kV lines into the stations have been replaced. The circuit switchers were originally specified for 230 kV operation. When they were replaced, ENWIN sought and received confirmation from Hydro One that the 115 kV circuits would never be upgraded to 230 kV and that it would be acceptable to replace them with units rated only for 115 kV. So, the original devices were replaced with units rated only for 115 kV operation.

**Topic**

**Feedback**

What other information should be considered in the continued development of these solutions leading up to the recommendations?

## West of London Bulk Study

**Topic**

**Feedback**

What feedback do you have regarding any of the options proposed?

**Topic**

**Feedback**

What other information should be considered in the continued development of these solutions leading up to the recommendations?

## General Comments/Feedback