

Ontario Implementation Plans

Enforcement Dates for

PRC-019-2, PRC-024-2, MOD-025-2, MOD-026-1 and MOD-027-1

Updated October 29, 2024

Standard	Requirement	Enforcement Date ^{1,2}	
		BES Elements Identified Prior to July 1, 2014	BES Elements Identified After July 1, 2014
PRC-019-2	All	July 1, 2018 (40%) July 1, 2019 (60%) October 1, 2020 (80%) January 1, 2022 (100%)	July 1, 2018 (40%) July 1, 2019 (60%) October 1, 2020 (80%) January 1, 2022 (100%)
PRC-024-2	All	July 1, 2018 (40%) July 1, 2019 (60%) October 1, 2020 (80%) January 1, 2022 (100%)	July 1, 2018 (40%) July 1, 2019 (60%) October 1, 2020 (80%) January 1, 2022 (100%)
MOD-025-2	All	July 1, 2018 (40%) July 1, 2019 (60%) October 1, 2020 (80%) January 1, 2022 (100%)	July 1, 2018 (40%) July 1, 2019 (60%) October 1, 2020 (80%) January 1, 2022 (100%)
MOD-026-1	R1, and R3 – R6	July 1, 2014	July 1, 2018
	R2	July 1, 2018 (30%) October 1, 2020 (50%) January 1, 2025 (100%)	July 1, 2018 (30%) October 1, 2020 (50%) January 1, 2025 (100%)
MOD-027-1	R1, and R3 – R5	July 1, 2014	July 1, 2018
	R2	July 1, 2018 (30%) October 1, 2020 (50%) January 1, 2025 (100%)	July 1, 2018 (30%) October 1, 2020 (50%) January 1, 2025 (100%)

¹ The revised NERC BES definition came into effect in Ontario on July 1, 2014.

² Beyond the 100% implementation date of a standard, in instances where a generating unit either is or is expected to be on long-term outage with a planned return to service date that falls after the next verification test required by that standard, market participants will be required to complete the tests on that generator within six (6) months of its return of service.