

Ontario Enforcement Dates for PRC-028-1 IBR Standard Implementation Plan

Ontario Effective Date of PRC-028-1 – April 1, 2025	
Phased-In Enforcement Dates for Requirements R1 to R7	
BES Inverter-Based Resources (IBR) in commercial operation on or before April 1, 2025	April 1, 2028 (50%) January 1, 2030 (100%) If you only have one (1) BES IBR: April 1, 2028 (100%)
BES Inverter-Based Resources (IBR) entering commercial operation after April 1, 2025 but on or before October 1, 2026	October 1, 2026 (100%)
BES IBRs entering commercial operation after October 1, 2026	Commercial Operation Date (100%)
Enforcement Date for Requirement R8 – No later than January 1, 2026	

- Non-BES Inverter-Based Resources are those that either have or contribute to an aggregate nameplate capacity of greater than or equal to 20 MVA, connected through a system designed primarily for delivering such capacity to a common point of connection at a voltage greater than or equal to 50 kV.
- In Ontario, Non-BES Inverter-Based Resources are subject to the IESO's connection requirements.