



Reliability Outlook

An adequacy assessment of Ontario's
electricity system

January 2023 to June 2024

Executive Summary

Ontario's power system is prepared for the next 18 months, with sufficient electricity resources expected to be available to meet customer needs. However, tightening conditions on the grid may require active outage management and increased import volumes during certain periods.

With nuclear refurbishments underway, retirements scheduled to begin, and some generation contracts set to expire, Ontario has entered a period when generation and transmission outages will be more challenging to accommodate. These conditions, which are likely to persist for the foreseeable future, will require active coordination and planning between market participants and the IESO to maintain reliability.

The IESO expects to have sufficient reserves for the winters of 2022/23 and 2023/24. Reserve shortages have the potential to appear in summer 2023, primarily as a result of coincident generator outages. The IESO is working with participants to reschedule outages and maintain system adequacy through this period. If outages cannot be moved, Ontario may have to rely on more supply from other jurisdictions and/or additional operating procedures in order to ensure reliability under extreme weather conditions.

The IESO secures forward capacity through different mechanisms, including an annual capacity auction. The results of the December 2022 Capacity Auction were announced on December 8, but were not available at the time this assessment was completed. The assessments in this report assumed 1,200 MW would be acquired in the auction, which was the target amount. However, the auction cleared over 1,400 MW, which will further contribute to reducing the reserve shortfall that appears in this report.

Electricity demand is expected to decline slightly in 2023 to 135.8 terawatt-hours (TWh), a drop of 0.5% compared to 2022. Peak demands are expected to be slightly lower than previously forecast due to lower levels of economic activity. Electricity demand is very closely tied to economic activity, and there are a number of factors influencing Ontario's economic outlook over the next 18 months. As is the case in other parts of the world, Ontario's economic activity has weakened in response to a number of external forces, including the pandemic, geopolitical tensions, supply chain disruptions and rising inflation.

Overall electricity demand – both peaks and energy – is expected to rise in 2024 as economic demand strengthens, supply chains normalize, and inventories build back up. Ontario's long-term demand forecast shows strong growth due to electrification and new development in the mining, agricultural and industrial sectors.

Ontario's transmission system is expected to reliably supply province-wide demand for the next 18 months. That said, there are a significant number of major generation and transmission projects currently underway or starting soon. As the timing of several projects overlap with each other and may require multiple equipment outages, reliability assessments will require

close coordination. Transmitters and generators are strongly encouraged to plan ahead, submit outage requests early, and coordinate regularly with the IESO and with each other to ensure system adequacy.



Table of Contents

Executive Summary	1
1. Introduction	6
2. Updates to this Outlook	7
2.1 Updates to the Demand Forecast	7
2.2 Updates to Resources	7
2.3 Updates to the Transmission Outlook	7
2.4 Updates to the Operability Outlook	7
3. Demand Forecast	8
4. Resource Adequacy	13
4.1 Assessment Assumptions	14
4.1.1 Generation Resources	14
4.1.2 Generation Capability	16
4.1.3 Demand Measures	18
4.1.4 Firm Transactions	18
4.1.5 Summary of Scenario Assumptions	19
4.2 Capacity Adequacy Assessment	21
4.2.1 Firm Scenario with Normal and Extreme Weather	21
4.2.2 Planned Scenario with Normal and Extreme Weather	22
4.2.3 Comparison of the Current and Previous Weekly Adequacy Assessments for the Firm Extreme Weather Scenario	23
4.3 Energy Adequacy Assessment	24
4.3.1 Summary of Energy Adequacy Assumptions	24
4.3.2 Results – Firm Scenario with Normal Weather	25
4.3.3 Findings and Conclusions	25
5. Transmission Reliability Assessment	28

5.1	Transmission Projects	28
5.2	Transmission Outages	28
5.3	Transmission Considerations	28
6.	Operability	31
6.1	Outage Management Considerations	31
6.2	Surplus Baseload Generation	32
6.3	Ancillary Services	32
6.3.1	Regulation Service	32
7.	Resources Referenced in This Report	33
8.	List of Acronyms	34

List of Figures

Figure 4-1 Monthly Wind Capacity Contribution Values	17
Figure 4-2 Monthly Solar Capacity Contribution Values	18
Figure 4-3 Comparison of Normal and Extreme Weather: Firm Scenario Reserve Above Requirement	22
Figure 4-4 Comparison of Normal and Extreme Weather: Planned Scenario Reserve Above Requirement	23
Figure 4-5 Comparison of Current and Previous Outlook: Firm Scenario Extreme Weather Reserve Above Requirement	24
Figure 4-6 Forecast Energy Production by Fuel Type	26
Figure 4-7 Forecast Monthly Energy Production by Fuel Type	27

List of Tables

- Table 3-1 | Forecast Energy Demand Summary 8**
- Table 3-2 | Forecast Seasonal Peaks 9**
- Table 3-3 | Weekly Energy and Peak Demand Forecast 9**
- Table 4-1 | Existing Grid-Connected Resource Capacity14**
- Table 4-2 | Committed Generation Resources Status.....15**
- Table 4-3 | Monthly Historical Hydroelectric Median Values for Normal Weather Conditions.....16**
- Table 4-4 | Summary of Available Resources under Normal Weather20**
- Table 4-5 | Summary of Zonal Energy for Firm Scenario Normal Weather25**
- Table 4-6 | Energy Production by Fuel Type for the Firm Scenario Normal Weather 27**
- Table 7-1 | Additional Resources33**



1. Introduction

This Outlook covers the 18 months from January 2023 to June 2024, and supersedes the Outlook released on September 22, 2022.

The purpose of the 18-month horizon in the *Reliability Outlook* is to:

- Advise market participants of the resource and transmission reliability of the Ontario electricity system
- Assess potentially adverse conditions that might be avoided by adjusting or coordinating maintenance plans for generation and transmission equipment
- Report on initiatives being implemented to improve reliability within this time frame

This Outlook assesses resource and transmission adequacy based on the stated assumptions, following the [Methodology to Perform the Reliability Outlook](#). Due to uncertainties associated with various assumptions, readers are encouraged to use their judgment in considering possible future scenarios.

Additional supporting documents are located on the [IESO website](#).

[Security and adequacy assessments](#) are published on the IESO website on a daily basis and progressively supersede information presented in this report.

For questions or comments on this Outlook, please contact us at 905-403-6900 (toll-free 1-888-448-7777) or customer.relations@ieso.ca.



2. Updates to this Outlook

2.1 Updates to the Demand Forecast

The demand forecast used in this Outlook is informed by actual demand, weather and economic data through to the end of September 2022, and has been updated to reflect the most recent economic projections. Actual weather and demand data for October and November 2022 are included in the [tables](#).

2.2 Updates to Resources

This *Reliability Outlook* considers planned generator outages over the 18-month period, submitted by market participants to the IESO's outage management system as of December 2, 2022. Market participants are required annually to submit information to enable the IESO to conduct reliability assessments. This information, provided to the IESO through Form 1230, was submitted by April 1, 2022.

2.3 Updates to the Transmission Outlook

This Outlook also considers transmission outage plans that were submitted to the IESO's outage management system by November 8, 2022.

2.4 Updates to the Operability Outlook

Results of an updated Regulation Service needs assessment, conducted in 2022, are discussed in the Operability Outlook.

3. Demand Forecast

Electricity demand is expected to fall to 135.8 TWh in 2023, a projected reduction of 0.5%. This follows higher growth in each of the previous two years: 1.4% in 2021 (133.7 TWh) and a projected 2.1% in 2022 (136.5 TWh). The IESO is closely monitoring major global macroeconomic and geopolitical factors that are likely to impact electricity demand over the 18-month horizon and will revise these forecasts accordingly.

The IESO is responsible for forecasting electricity demand on the IESO-controlled grid. This demand forecast covers the period from January 2023 to June 2024 and supersedes the previous forecast released in September 2022. Tables of supporting information are contained in the [2022 Q4 Outlook Tables](#).

Electricity demand is very closely tied to economic activity, and there are a number of important factors influencing Ontario’s economic outlook over the next 18 months, including supply chain disruptions, inflation and interest rates. Economic output may weaken in 2023 before rebounding in 2024 as economic demand strengthens, supply chains normalize, and inventories build back up.

Peak demands are expected to be slightly lower in 2023 than previously forecast due to lower levels of economic activity underpinning those peaks. Additionally, 2023 energy demand is projected to decline by 0.5% compared to 2022 due to the economic outlook. Toward the end of the forecast period, overall electricity demand – both peaks and energy – is expected to trend upward.

In addition to the short-term economic outlook, other factors are affecting the demand for electricity. The post-pandemic effect of work from home and remote working still make the grid more sensitive to temperature. Conversely, the Industrial Conservation Initiative (ICI) acts to reduce peak demands from the commercial and industrial sectors. Storage options, self-generation and other technological advancements are enabling participants to more effectively avoid peak system demands and increase their ICI savings.

The demand forecast faces significant uncertainties, including economic outlooks and geopolitical events.

Table 3-1 | Forecast Energy Demand Summary

Year	Normal Weather Energy (TWh)	% Growth in Energy
2023	135.8	-0.5%
2024	137.4	1.2%

Table 3-2 | Forecast Seasonal Peaks

Season	Normal Weather Peak (MW)	Extreme Weather Peak (MW)
Winter 2022-23	21,170	22,524
Summer 2023	22,474	24,457
Winter 2023-24	21,336	22,612

Table 3-3 | Weekly Energy and Peak Demand Forecast

Week Ending	Normal Peak (MW)	Extreme Peak (MW)	Load Forecast Uncertainty (MW)	Normal Energy Demand (GWh)
01-Jan-23	19,886	21,093	362	2,668
08-Jan-23	20,292	21,400	528	2,764
15-Jan-23	20,751	21,973	570	2,872
22-Jan-23	20,920	22,098	547	2,897
29-Jan-23	21,170	22,524	483	2,915
05-Feb-23	20,892	21,919	404	2,885
12-Feb-23	20,758	21,737	734	2,857
19-Feb-23	20,339	21,587	635	2,849
26-Feb-23	20,136	21,749	581	2,804
05-Mar-23	19,724	21,334	501	2,774
12-Mar-23	19,546	21,026	531	2,720
19-Mar-23	18,842	20,308	649	2,673
26-Mar-23	18,411	19,924	611	2,607
02-Apr-23	18,071	19,189	569	2,542

Week Ending	Normal Peak (MW)	Extreme Peak (MW)	Load Forecast Uncertainty (MW)	Normal Energy Demand (GWh)
09-Apr-23	17,831	18,650	567	2,460
16-Apr-23	17,683	18,190	471	2,460
23-Apr-23	17,214	18,195	496	2,434
30-Apr-23	16,873	17,694	531	2,375
07-May-23	17,017	18,845	721	2,361
14-May-23	17,024	19,473	849	2,344
21-May-23	17,153	20,958	845	2,367
28-May-23	17,350	20,731	1,175	2,297
04-Jun-23	18,912	21,216	1,330	2,388
11-Jun-23	19,314	21,784	1,292	2,418
18-Jun-23	20,838	22,194	1,055	2,484
25-Jun-23	21,533	22,956	835	2,527
02-Jul-23	21,931	23,676	754	2,558
09-Jul-23	22,287	24,183	1,016	2,652
16-Jul-23	22,248	24,278	814	2,681
23-Jul-23	22,405	24,457	838	2,730
30-Jul-23	22,474	24,456	1,035	2,766
06-Aug-23	22,280	24,413	841	2,789
13-Aug-23	22,250	24,257	958	2,729
20-Aug-23	22,158	24,413	985	2,753
27-Aug-23	22,431	24,256	1,362	2,713
03-Sep-23	22,184	24,211	1,413	2,693
10-Sep-23	21,554	23,518	1,370	2,565

Week Ending	Normal Peak (MW)	Extreme Peak (MW)	Load Forecast Uncertainty (MW)	Normal Energy Demand (GWh)
17-Sep-23	21,440	22,710	680	2,543
24-Sep-23	20,318	21,953	781	2,469
01-Oct-23	18,645	21,011	420	2,420
08-Oct-23	17,716	19,468	554	2,395
15-Oct-23	17,453	18,588	786	2,343
22-Oct-23	17,364	17,964	507	2,396
29-Oct-23	17,632	19,001	392	2,429
05-Nov-23	17,849	19,423	318	2,457
12-Nov-23	18,421	19,801	416	2,495
19-Nov-23	18,947	19,519	601	2,561
26-Nov-23	19,610	20,105	342	2,629
03-Dec-23	19,804	20,682	607	2,681
10-Dec-23	20,260	21,217	409	2,731
17-Dec-23	20,390	21,671	555	2,759
24-Dec-23	20,251	21,610	690	2,779
31-Dec-23	19,471	20,799	362	2,635
07-Jan-24	20,498	21,553	528	2,799
14-Jan-24	20,966	22,103	570	2,901
21-Jan-24	21,083	22,188	547	2,924
28-Jan-24	21,336	22,612	483	2,941
04-Feb-24	21,246	22,403	404	2,918
11-Feb-24	20,920	21,821	734	2,880
18-Feb-24	20,504	21,673	635	2,877

Week Ending	Normal Peak (MW)	Extreme Peak (MW)	Load Forecast Uncertainty (MW)	Normal Energy Demand (GWh)
25-Feb-24	20,298	21,829	581	2,829
03-Mar-24	20,205	21,776	501	2,816
10-Mar-24	19,644	21,142	531	2,748
17-Mar-24	19,149	20,633	649	2,702
24-Mar-24	18,598	20,029	611	2,634
31-Mar-24	18,135	19,273	569	2,535
07-Apr-24	17,899	18,738	567	2,511
14-Apr-24	17,759	18,286	471	2,494
21-Apr-24	17,678	18,279	496	2,461
28-Apr-24	17,475	17,765	531	2,400
05-May-24	17,706	18,953	721	2,388
12-May-24	17,368	19,550	849	2,367
19-May-24	17,736	20,999	845	2,388
26-May-24	17,565	20,950	1,175	2,329
02-Jun-24	19,097	21,332	1,330	2,408
09-Jun-24	19,425	21,824	1,292	2,438
16-Jun-24	20,999	22,272	1,055	2,508
23-Jun-24	21,720	23,065	835	2,565
30-Jun-24	22,325	23,995	754	2,630

4. Resource Adequacy

Ontario has entered a period during which generation and transmission outages will be increasingly difficult to accommodate. The IESO expects these conditions to persist for the foreseeable future. Market participants are strongly encouraged to plan ahead and coordinate with the IESO to ensure planned outages can be appropriately scheduled.

The IESO expects to have sufficient reserves for the winters of 2022/23 and 2023/24. Significant reserve shortages have the potential to appear in summer 2023, primarily as a result of coincident generator outages. Should market participants be unable to reschedule certain outages during this period, Ontario may have to rely on more than 2,000 MW of supply from other jurisdictions and/or additional operating actions in order to ensure reliability under extreme weather conditions.

This section assesses the adequacy of resources to meet the forecast demand. Resource adequacy is one of the reliability considerations used for approving generation and transmission outages. When reserves are below required levels, with potentially adverse effects on the reliability of the grid, the IESO will reject outage requests based on their order of precedence. Conversely, when reserves are above required levels, additional outages can be contemplated, provided other factors – such as local considerations, operability or transmission security – do not pose a reliability concern. In those cases, the IESO may place an outage at risk, signaling to the facility owner to consider rescheduling the outage.

Ontario's existing installed generation capacity is summarized in Table 4-1. The forecast capability at the Outlook peak is based on the firm resource scenario, which includes resources currently in commercial operation, and takes into account deratings, planned outages and an allowance for capability levels below rated installed capacity.

Table 4-1 | Existing Grid-Connected Resource Capacity

Fuel Type	Total Installed Capacity (MW)	Forecast Capability at 2023 Summer Peak Normal Weather (MW)	Forecast Capability at 2023 Summer Peak Extreme Weather (MW)	Number of Stations	Change in Number of Stations	Change in Installed Capacity
Nuclear	13,089	8,759	7,986	5	0	0
Hydroelectric	8,868	5,485	4,826	76	0	0
Gas/Oil	10,482	9,221	8,820	33	0	0
Wind	4,883	761	761	41	0	0
Biofuel	296	286	286	7	0	0
Solar	478	126	126	10	0	0
Demand Measures	-	850	850	-	-	-
Firm Imports (+) / Exports (-) (MW)	-	0	0	-	-	-
Total	38,096	25,488	23,655	172	0	0

4.1 Assessment Assumptions

4.1.1 Generation Resources

All generation resources scheduled to come into service, be upgraded or be shut down within the Outlook period are summarized in Table 4-2. This includes generation projects in the IESO's connection assessment and approval (CAA) process, those under construction, and contracted resources. Details regarding the IESO's CAA process and the status of these projects can be found on the [Application Status](#) section of the IESO website.

The estimated effective date column in Table 4-2 indicates when the market registration process is expected to be complete for each generation resource, based on information available to the IESO as of September 6, 2022. Two scenarios are used to describe project risks:

- The **planned scenario** assumes that all resources scheduled to come into service are available over the assessment period.
- The **firm scenario** assumes that only resources that have reached commercial operation status and completed commissioning at the time this assessment was completed are available.

Planned shutdowns or permanent¹ retirements of generators that have a high likelihood of occurring are considered for both scenarios.

Table 4-2 | Committed Generation Resources Status

Project Name	Zone	Fuel Type	Estimated Effective Date	Project Status	Firm (MW)	Planned (MW)
Romney	West	Wind	2023-Q1	Commissioning		60
Beck 1 New G1 ²	Niagara	Hydro	2023-Q1	Commissioning		59
Beck 1 New G2	Niagara	Hydro	2023-Q1	Commissioning		59
Total						178

Notes on Table 4-2:

The total may not add up due to rounding and does not include in-service facilities. Project status provides an indication of the project progress, using the following terminology:

- Under Development – projects in approvals and permitting stages (e.g., environmental assessment, municipal approvals, IESO connection assessment approvals) and projects under construction
- Commissioning – projects undergoing commissioning tests with the IESO
- Commercial Operation – projects that have achieved commercial operation status under the contract criteria, but have not met all of the IESO’s market registration requirements
- Expiring Contract – contracts that will expire during the Outlook period are included in both scenarios only up to their contract expiry date. Generators (including non-utility generators) that continue to provide forecast output data are also included in the planned scenario for the rest of the 18-month period.

¹ Given the evolving nature of resource acquisitions and commitments in Ontario, Table 4-2 will be listing new resources as they commission and existing resources that are expected to permanently retire or mothball at the end of their current commitments.

² “New Beck” units are the [previously removed and now replaced](#) G1 and G2.

4.1.2 Generation Capability

Hydroelectric

A monthly forecast of hydroelectric generation output is calculated based on median historical values of hydroelectric production and contribution to operating reserve during weekday peak demand hours. Through this method, routine maintenance and actual forced outages of the generating units are implicitly accounted for in the historical data (see the first row in Table 4-3).

To reflect the impact of hydroelectric outages on the reserve above requirement (RAR) and allow the assessment of hydroelectric outages as per the outage approval criteria, the hydroelectric capability is also calculated, without accounting for historical outages (see the second row of Table 4-3). Table 4-3 uses data from May 2002 to March 2022, which are updated annually to coincide with the release of the Q2 Outlook.

Table 4-3 | Monthly Historical Hydroelectric Median Values for Normal Weather Conditions

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Historical Hydroelectric Median Contribution (MW)	6,130	6,054	5,874	5,891	5,922	5,735	5,570	5,274	5,056	5,420	5,674	6,126
Historical Hydroelectric Median Contribution without Outages (MW)	6,630	6,633	6,395	6,406	6,366	6,237	6,105	5,859	5,909	6,228	6,449	6,639


Thermal Generators

Thermal generators' capacity, planned outages and deratings are based on market participant submissions. Forced outage rates on demand are calculated by the IESO based on actual operational data. The IESO will continue to rely on market participant-submitted forced outage rates for comparison purposes.

Wind

For wind generation, monthly wind capacity contribution (WCC) values from the weekday peak hour are used. The process for determining wind contribution can be found in the [Methodology to Perform the Reliability Outlook](#). Figure 4-1 shows the monthly WCC values, which are updated annually with the release of the Q2 Outlook.


Figure 4-1 | Monthly Wind Capacity Contribution Values



Solar

For solar generation, monthly solar capacity contribution (SCC) values from the weekday peak hour are used. Information on how the solar contribution is calculated can be found in the [Methodology to Perform the Reliability Outlook](#). Figure 4-2 shows the monthly SCC values, which are updated annually for the release of the Q2 Outlook.

Figure 4-2 | Monthly Solar Capacity Contribution Values



4.1.3 Demand Measures

Both demand measures and load modifiers can impact demand, but differ in how they are treated within the Outlook. Demand measures, such as dispatchable loads and demand response procured through the IESO’s [capacity auction](#), are not incorporated into the demand forecast and are instead treated as resources. Load modifiers are incorporated into the demand forecast. The impacts of activated demand measures are added back into the demand history prior to forecasting demand for future periods.

4.1.4 Firm Transactions

Capacity-Backed Exports

The IESO allows Ontario resources to compete in the capacity auctions held by certain neighbouring jurisdictions, but only if Ontario has adequate supply. New York Independent System Operator (NYISO) will allow up to 23 MW of capacity-backed exports from Ontario between November 2022 and April 2023.

System-Backed Exports

As part of the electricity trade agreement between Ontario and Quebec, Ontario will supply 500 MW of capacity to Quebec for winter months from December 2022 to March 2023. In addition, Ontario will receive up to 2.3 TWh of clean energy annually, scheduled economically via Ontario’s real-time markets. The economically imported energy will target peak hours to help reduce greenhouse gas emissions in Ontario. The agreement includes the opportunity to cycle energy.

As part of this capacity exchange agreement, Ontario can call on 500 MW of capacity during summer before September 2030, based on the province's needs. Ontario does not expect to call on this capacity during this 18-month period (as discussed in the [2022 Annual Acquisition Report](#), the IESO expects to exercise this option in the summer of 2026).

4.1.5 Summary of Scenario Assumptions

To assess future resource adequacy, the IESO must make assumptions about the amount of available resources. The Outlook considers two scenarios: a firm scenario and a planned scenario.

The starting point for both scenarios is the existing installed resources shown in Table 4-1. The planned scenario assumes that all resources scheduled to come into service are available over the assessment period. The firm scenario considers only those resources that have reached commercial operation status as of the time of this assessment. Generator-planned shutdowns or retirements that have a high likelihood of occurring are considered for both scenarios. They also both reflect planned outages submitted by generators. Table 4-4 shows the available resources that are forecast over the 18-month Outlook, under both scenarios in normal weather conditions, and at the time of the summer and winter peak demands.

Table 4-4 | Summary of Available Resources under Normal Weather

Notes	Description	Winter Peak	Winter Peak	Summer	Summer	Winter Peak	Winter Peak
		2022/2023	2022/2023	Peak 2023	Peak 2023	2023/2024	2023/2024
		Firm Scenario	Planned Scenario	Firm Scenario	Planned Scenario	Firm Scenario	Planned Scenario
1	Installed Resources (MW)	38,096	38,273	38,096	38,273	38,096	38,273
2	Total Reductions in Resources (MW)	11,836	12,014	13,458	13,545	12,083	12,260
3	Demand Measures (MW)	614	614	850	850	798	798
4	Firm Imports (+) / Exports (-) (MW)	-523	-523	0	0	0	0
5	Available Resources (MW)	26,351	26,350	25,488	25,578	26,811	26,811
6	Bottling (MW)	1,557	1,668	0	0	828	828
7	Available Resources without Bottling (MW)	27,908	28,018	25,488	25,578	27,638	27,639

Notes on Table 4-4:

1. Installed Resources: The total generation capacity assumed to be installed at the time of the summer and winter peaks.
2. Total Reductions in Resources: The sum of deratings, planned outages, limitations due to transmission constraints and allowances for capability levels below rated installed capacity.
3. Demand Measures: The amount of demand reduction expected to be available at the time of peak.
4. Firm Imports/Exports: The amount of expected firm imports and exports at the time of summer and winter peaks.
5. Available Resources: Installed Resources (line 1) minus Total Reductions in Resources (line 2) plus Demand Measures (line 3) and Firm Imports/Exports (line 4). This differs from the Forecast Capability at System Peak shown in Table 4-1 due to the impacts of generation bottling (transmission limitations).
6. Available Resources without Bottling: Available resources after they are reduced due to bottling.

4.2 Capacity Adequacy Assessment

The capacity adequacy assessment accounts for zonal transmission constraints resulting from planned transmission outages assessed as of November 8, 2022. The generation planned outages occurring during this Outlook period have been assessed as of December 2, 2022.

4.2.1 Firm Scenario with Normal and Extreme Weather

The firm scenario incorporates all capacity that had achieved commercial operation status as of December 2, 2022.

Figure 4-3 shows Reserve Above Requirement (RAR) levels, which represents the difference between available resources and required resources. The required resources equals forecast demand plus the required reserve.

Capacity secured in the December 2021 Capacity Auction (CA) has been included in this assessment. The target capacity for the December 2022 Capacity Auction, as announced in the IESO's [Annual Acquisition Report](#), has been included and modelled as demand measures in the firm resource scenario for summer 2023 and winter 2023/24³.

The IESO expects to have sufficient reserves for the winters of 2022/23 and 2023/24. In the firm scenario under normal weather conditions, available reserves fall below the requirement for seven weeks in summer 2023. In the firm scenario under extreme weather conditions, the reserve is lower than the -2,000 MW adequacy threshold for nine weeks in summer 2023. Under the current outage schedule, the RAR is below the adequacy threshold for the nine-week period from July 3 to September 3, 2023.


These potential shortfalls are primarily attributed to planned generator outages scheduled during those weeks, including a large number of coincident nuclear outages. The IESO is working closely with participants that have planned outages during this period to ensure Ontario maintains adequate reserves. However, should those participants be unable to reschedule certain outages during periods of low reserves, Ontario may have to rely on more than 2,000 MW of supply from other jurisdictions and/or additional operating actions in order to ensure reliability under extreme weather conditions. Likewise, Ontario may have to rely on some imports to meet demand under normal weather conditions.

Outage requests during periods when reserves fall below the adequacy threshold under extreme weather conditions will be put at risk and may be rejected should those conditions materialize. The IESO will continue to work with both generators and transmitters to ensure outages are appropriately scheduled.

³ Results of the December 2022 Capacity Auction were not available at the time this assessment was completed. The target assumed in the resource assessment was 1200 MW for summer 2023; in fact, the CA cleared over 1400 MW. Capacity auction results can be found in the post-auction report on the [IESO's webpage](#), and will be included in the firm scenario in future outlooks.

As Ontario enters a period of tighter supply conditions, planned generator maintenance outages will become increasingly difficult to schedule. Generators are advised not to schedule outages during periods when reserves are forecast to be low, and are strongly encouraged to plan ahead and coordinate the timing of outages with IESO staff.

Figure 4-3 | Comparison of Normal and Extreme Weather: Firm Scenario Reserve Above Requirement




4.2.2 Planned Scenario with Normal and Extreme Weather

The Planned scenario incorporates all existing capacity, as well as all capacity expected to come into service. Approximately 178 MW of new generation capacity is expected to connect to Ontario’s grid over this Outlook period.

Figure 4-4 shows RAR levels under the Planned scenario. Reserves fall below requirements for five weeks in 2023 under normal weather conditions. Under the extreme weather scenario, reserves fall short for nine weeks in the summer of 2023.


Figure 4-4 | Comparison of Normal and Extreme Weather: Planned Scenario Reserve Above Requirement



4.2.3 Comparison of the Current and Previous Weekly Adequacy Assessments for the Firm Extreme Weather Scenario

Figure 4-5 compares forecast RAR values in the current Outlook with those in the previous Outlook, which was published on June 23, 2022. The difference is primarily the result of changes in planned outages.

Figure 4-5 | Comparison of Current and Previous Outlook: Firm Scenario Extreme Weather Reserve Above Requirement



Resource adequacy assumptions and risks are discussed in detail in the [Methodology to Perform the Reliability Outlook](#).

4.3 Energy Adequacy Assessment

This section assesses energy adequacy to determine whether Ontario has sufficient supply to meet its forecast energy demands, while highlighting potential adequacy concerns during the Outlook time frame. At the same time, the assessment estimates the aggregate production by resource category to meet the projected demand based on assumed resource availability.

4.3.1 Summary of Energy Adequacy Assumptions

The energy adequacy assessment (EAA) uses the same set of assumptions as the capacity assessment outlined in Tables 4-1 and 4-2, which indicate the total capacity of committed resources and when they are expected to be available over the next 18 months. The monthly forecast of energy production capability, based on energy modelling results, is included in the [2022 Q3 Outlook Tables](#).

For the EAA, only the firm scenario in Table 4-5 with normal weather demand is assessed. The key assumptions specific to this assessment are described in the [Methodology to Perform the Reliability Outlook](#).

4.3.2 Results – Firm Scenario with Normal Weather

Table 4-5 summarizes the energy simulation results over the next 18 months for the Firm scenario with normal weather demand both for Ontario and for each transmission zone.

Table 4-5 | Summary of Zonal Energy for Firm Scenario Normal Weather

Zone	18-Month Energy Demand TWh	18-Month Energy Demand Average MW	18-Month Energy Production TWh	18-Month Energy Production Average MW	Net Inter- Zonal Energy Transfer TWh	Zonal Energy	
						Demand on Peak Day of 18- Month Period GWh	Available Energy on Peak Day of 18-Month Period GWh
Bruce	1.2	88.0	59.8	4,555.0	58.6	1.8	113.8
East	12.2	931.0	19.1	1,455.0	6.9	24.8	93.1
Essa	13.4	1,018.0	4.5	342.0	-8.9	28.6	15.3
Niagara	6.3	477.0	21.2	1,615.0	14.9	15.0	53.8
Northeast	15.7	1,193.0	15.6	1,188.0	-0.1	26.2	32.3
Northwest	6.6	499.0	6.9	522.0	0.3	12.2	20.1
Ottawa	13.0	990.0	0.7	50.0	-12.3	29.8	1.9
Southwest	40.9	3,114.0	8.2	627.0	-32.7	93.4	22.9
Toronto	73.6	5,608.0	52.3	3,986.0	-21.3	173.5	127.1
West	21.5	1,635.0	15.9	1,213.0	-5.6	52.6	77.5
Ontario	204.2	15,554.0	204.2	15,553.0	0.0	457.9	557.9

4.3.3 Findings and Conclusions

The EAA indicates that Ontario is expected to have sufficient supply to meet its forecast energy needs throughout the outlook period for the Firm scenario with normal weather demand, without having to rely on support from external jurisdictions, with the exception of the summer months in 2023. During this period, a large number of coincident generation outages suggest a possibility of unserved energy under normal weather conditions, and Ontario may require support from external jurisdictions in order to meet energy demand.

The figures and tables in this section are based on a simulation of the province’s power system, using the assumptions presented within the Outlook to assess whether Ontario will be energy adequate.

Figure 4-6 breaks down projected production by fuel type to meet Ontario’s energy demand for the next 18 months, while Figure 4-7 shows the expected production by fuel type for each month. The province’s energy exports and imports are not considered in this assessment. Table 4-6 summarizes these simulated production results by fuel type, for each year.

Figure 4-6 | Forecast Energy Production by Fuel Type




Figure 4-7 | Forecast Monthly Energy Production by Fuel Type




Table 4-6 | Energy Production by Fuel Type for the Firm Scenario Normal Weather

Fuel Type (Grid-Connected)	2022 (Oct 1 – Dec 31) (GWh)	2023 (Jan 1 – Dec 31) (GWh)	2024 (Jan 1 – Mar 31) (GWh)	Total (GWh)
Nuclear	16,237	72,025	17,391	105,653
Hydro	8,873	36,609	9,467	54,948
Gas & Oil	4,688	16,183	5,601	26,472
Wind	3,752	10,446	3,794	17,991
Biofuel	127	493	123	744
Other (Solar & DR)	270	782	204	1,256
Total	33,946	136,538	36,580	207,064

5. Transmission Reliability Assessment

Ontario's transmission system is expected to continue to reliably supply province-wide demand for the next 18 months, even while experiencing normal contingencies defined by planning criteria. However, some combinations of transmission and/or generation outages could create operating challenges. For this reason, it is – and will continue to be – increasingly difficult to schedule certain outages to avoid reliability concerns. The sheer volume of outage requests and the limited time periods available to complete the work will make scheduling a challenge for the foreseeable future.

The IESO assesses transmission adequacy using a methodology based on conformance to established criteria, including the [Ontario Resource and Transmission Assessment Criteria \(ORTAC\)](#), [NERC transmission planning standard TPL 001-4](#) and [NPCC Directory #1](#) as applicable. Planned system enhancements and projects, and known transmission outages are also considered in the studies.

5.1 Transmission Projects

This section considers the information transmitters have provided with respect to transmission projects that are planned for completion within the next 18 months. The list of transmission projects can be found in [Appendix B1](#). Note that the planned in-service dates in this table and throughout this document are as of November 2022. These dates are subject to change as the COVID-19 pandemic may impact project logistics. Any changes will be communicated through subsequent Reliability Outlooks.

5.2 Transmission Outages

The IESO's assessment of transmission outage plans is shown in [Appendix C, Tables C1 to C11](#). The methodology used to assess the transmission outage plans is described in the [Methodology to Perform the Reliability Outlook](#). This Outlook reflects transmission outage plans submitted to the IESO as of November 8, 2022.

5.3 Transmission Considerations

The purpose of this section of the report is to highlight projects and outages that may affect reliability and/or the scheduling of other outages, and to consolidate these considerations by zone. For more information about the IESO's transmission zones and interfaces, please see the [Transfer Capability Assessment Methodology](#).

Bruce, Southwest, and West Zones

Significant growth in the greenhouse sector has led to a number of customer connection requests in the Windsor-Essex region that are expected to exceed the capacity of the existing transmission system in the area. The new switching station (“Lakeshore TS”) at the Leamington Junction has been installed and all four of the existing circuits have been cut over. New loads are starting to connect to the first South Middle Rd. load station connected by radial circuits from Lakeshore TS, and work is on-going for the second load station. The new Lakeshore RAS has been installed, and resulting operational measures available will be restrictive over the course of this period. During this time, system resiliency will be reduced, and per [market rule exemption 1359](#), certain customers in the area may experience a lower level of reliability.

The following outages will impact the flow out of the Bruce zone:

- A planned two-week outage starting January 23, 2023, on circuit B560V, and another planned five-week outage starting September 18, 2023A planned four-week outage starting April 27, 2023, on circuit B501M
- A planned three-week outage starting June 26, 2023, on circuit B561M
- A planned six-week outage starting August 1, 2023, on circuit B502M

Toronto, East, and Ottawa Zones

Operational challenges due to high voltages in eastern Ontario and the Greater Toronto Area continue to occur during low-demand periods. High voltages are the result of lower minimum demand for electricity. The IESO and Hydro One have been managing this situation by removing from service certain 500 kV circuits, mainly in eastern Ontario and occasionally in the Bruce area during those periods. To address this issue on a longer-term basis, two 500 kV line-connected shunt reactors are being installed at Lennox TS. The first reactor has been installed and is in-service. The second reactor is expected to go into service in Q2 2023.

There are upcoming nuclear refurbishments of multiple units at Darlington with overlapping timelines. As a result, it will be increasingly challenging for market participants to take outages impacting the Flow East Towards Toronto (FETT) interface. Future planned outages will necessitate enhanced coordination between transmitters and generators. Planned outages for certain windows may need to be rescheduled or rejected to ensure reliability.

Of particular note, the FETT Capacity Upgrade (i.e., Richview-Trafalgar Reinforcement) project to address future needs is underway; the project is expected to be in-service date of Q1 2026.

The Hawthorne-Merivale transmission path supplies load in western Ottawa and delivers eastern Ontario resources, and imports from Quebec, to southern Ontario load centres. The reinforcement consists of upgrading the two 230 kV circuits between Merivale TS and Hawthorne TS, a length of 12 km. Hydro One began the project this year, with an expected in-service date of Q4 2023.

The following outages will impact the flow into Ottawa:

- A planned two-month outage starting April 3, 2023, on circuit X522A, and another planned six-week outage starting September 25, 2023

Northwest, Northeast, and Essa Zones

The following outages will reduce the transfer capability of the North-South tie:

- A five-week outage on circuit X504E starting May 29, 2023
- A four-week outage on circuit X503E starting October 2, 2023

The East-West Tie Expansion project consists of a new 230 kV transmission line roughly paralleling the existing East-West Tie Line between Wawa and Thunder Bay. The new line will increase the electricity transfer capability into Northwest Ontario and will improve the flexibility and efficiency of the Northwest electricity system. As part of this project, upgrades were planned for the Lakehead, Marathon and Wawa transformer stations to accommodate the new line. The project was placed in-service at the end of Q1 2022. However, the full benefit of the project will not be realized right away due to ongoing and upcoming outages as a result of work in the Northwest.

In the Kirkland Lake area, a new RAS is planned to be in service in December 2023 that will enable load rejection, eliminating the need for pre-contingency load curtailment. The Ansonville to Kirkland Lake A8K/A9K transmission circuit refurbishment is planned to be in-service by Q2 2023, improving transmission system capacity in the area.

The “Barrie Area Transmission Upgrade” project is expected to come into service in Q4 2023. This project will convert the existing Barrie TS and its supply lines from Essa TS (circuits E3B and E4B) from 115 kV to 230 kV, enabling additional load to be supplied from Barrie TS. The existing 230/115 kV auto-transformers at Essa TS will no longer be needed after this conversion and will be retired.

Interconnections

Phase Angle Regulators (PARs) are unique pieces of equipment and replacements are not readily available. Replacement options were investigated by the IESO, in conjunction with Hydro One, the NYISO and the New York Power Authority. The proposed replacement will provide greater flexibility to control both current and future intertie flows with New York. The PAR on L33P is now in-service, as of Q3 2022. The PAR on L34P is being replaced to match L33P; it is currently out of service for replacement work, and has an expected in-service date of Q4 2023.

6. Operability

Ontario is entering a period of tighter supply conditions; surplus baseload generation is not expected to be a significant issue for the foreseeable future. The IESO will continue to assess other aspects of operability and report on them in future Outlooks where appropriate.

This section highlights existing or emerging operability issues that could impact the reliability of Ontario's power system.

Operability refers to the IESO's ability to manage a variety of conditions on the power system as they occur in real-time. The IESO works to ensure that the power system is reliable under changing system conditions, variability of supply and fluctuations in load, while respecting thermal, voltage and transient stability limits on the system. Operability is assessed in advance to ensure that the power system is adequately prepared for expected real-time conditions, while also having the ability to absorb and adapt to unexpected changes.

6.1 Outage Management Considerations

Ontario is entering a period during which generation and transmission outages will be increasingly difficult to accommodate. In addition to meeting global Ontario adequacy needs, transmission adequacy and security must be safeguarded.

There are a significant number of major generation and transmission projects either currently underway or expected to begin in the near future. As the timing of many of these projects overlap with each other and can require multiple equipment outages, reliability assessments are increasingly complex. An example mentioned earlier describes major projects that are related to the Flow East Towards Toronto (FETT) interface.

With consideration of equipment failure, tighter supply conditions and other factors such as supply chain delays, some outages may need to be rejected and rescheduled. Transmitters and generators are strongly encouraged to plan ahead, coordinate with one another, submit outage requests early, and coordinate with the IESO; scheduling outages at desired times may still be difficult due to the significant number of major projects that are planned for the same time. Furthermore, outages are not guaranteed as unanticipated equipment failures may change reliability assessments.

One important aspect of grid equipment outages is recall time. Recall times indicate how long it takes for equipment on outage to return to service. Minimizing recall times increases the likelihood of outages being approved. If many outages are non-recallable, it can be difficult to accommodate additional outages as there needs to be a reliable plan to restock the system after an equipment failure occurs on the grid. If multiple equipment failures occur, there may be instances where outage management alone will not address the concern. Under such circumstances the IESO may need to rely on additional non-firm imports or emergency operating procedures in order to ensure reliability. More information on actions the IESO can take to ensure reliability can be found in [Market Manual 7.1: IESO Controlled Grid Operating Procedures](#).

6.2 Surplus Baseload Generation

Ontario is entering a period of tighter supply conditions. Surplus baseload generation is not expected to be a significant issue for the foreseeable future and for this reason, forecasts for SBG are no longer being produced.

6.3 Ancillary Services

Ancillary services are services that help ensure the reliable operation of the power system. The IESO contracts for four ancillary services: certified black start facilities, regulation service, reactive support and voltage control service, and reliability must-run. The IESO regularly studies the needs for these services. Salient details of recent studies are presented below.

6.3.1 Regulation Service

The 2022 regulation needs assessment updates the assessment identified in the previous *Reliability Outlook*, based on incremental improvements. The assessment found that there may be an increased need for regulation service in the upcoming years. The IESO is currently considering options to address the potential need for more regulation.

7. Resources Referenced in This Report

The table below lists additional resources in the order they appear in the report.

Table 7-1 | Additional Resources

Resource	URL	Location in This Report
Reliability Outlook Webpage	http://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Reliability-Outlook	Introduction
Security and Adequacy Assessments	http://www.ieso.ca/power-data/data-directory	Introduction
2022 Q4 Outlook Tables	http://www.ieso.ca/-/media/files/ieso/document-library/planning-forecasts/reliability-outlook/ReliabilityOutlookTables_2022Dec.xls	Throughout
Connection Assessments and Approval Process	http://www.ieso.ca/en/sector-participants/connection-assessments/application-status	Assessment Assumptions
Methodology to Perform the Reliability Outlook	http://www.ieso.ca/-/media/files/ieso/document-library/planning-forecasts/reliability-outlook/ReliabilityOutlookMethodology.pdf	Throughout
Capacity Auction	http://www.ieso.ca/en/Sector-Participants/Market-Operations/Markets-and-Related-Programs/Capacity-Auction	Demand Measures
Enabling Capacity Exports	http://www.ieso.ca/en/Sector-Participants/Market-Renewal/Capacity-Exports	Firm Transactions
Ontario Resource and Transmission Assessment Criteria	https://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/connecting/IMO-REQ-0041-TransmissionAssessmentCriteria.ashx	Transmission Considerations
NERC Transmission Planning Standard TPL-001-4	http://www.nerc.com/pa/Stand/Reliability%20Standards/TPL-001-4.pdf	Transmission Considerations
NPCC Directory #1	https://www.npcc.org/Standards/Directories/Directory_1_TFCP_rev_20151001_GJD.pdf https://www.npcc.org/content/docs/public/program-areas/standards-and-criteria/regional-criteria/directories/directory-01-design-and-operation-of-the-bulk-power-system.pdf	Transmission Considerations
Market Manual 4 Part 4.2	http://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/market-operations/mo-dispatchdatarm.pdf?la=en	Surplus Baseload Generation
Market Manual 7.1	https://www.ieso.ca/en/sector-participants/market-operations/-/media/ccdae55168cc4ae8a4b73894ba305ebe.ashx	Operability
Annual Acquisition Report	https://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Annual-Acquisition-Report	Resource Adequacy

8. List of Acronyms

Acronym	Definition
CAA	Connection Assessment and Approval
DR	Demand Response
EAA	Energy Adequacy Assessment
FETT	Flow East Toward Toronto
GS	Generating Station
GTA	Greater Toronto Area
ICI	Industrial Conservation Initiative
IESO	Independent Electricity System Operator
IRRP	Integrated Regional Resource Plan
kV	Kilovolt
LDC	Local Distribution Company
MW	Megawatt(s)
NERC	North American Electric Reliability Corporation
NPCC	Northeast Power Coordinating Council
NYISO	New York Independent System Operator
ORTAC	Ontario Resource and Transmission Criteria
PAR	Phase Angle Regulator
RAR	Reserve Above Requirement
RAS	Remedial Action Scheme
SBG	Surplus Baseload Generation
SCC	Solar Capacity Contribution
TS	Transmission/Transformer Station
TWh	Terawatt-hour(s)
WCC	Wind Capacity Contribution

**Independent Electricity
System Operator**

1600-120 Adelaide Street West
Toronto, Ontario M5H 1T1

Phone: 905.403.6900

Toll-free: 1.888.448.7777

E-mail: customer.relations@ieso.ca

ieso.ca



[@IESO Tweets](https://twitter.com/IESO)



facebook.com/OntarioIESO



linkedin.com/company/IESO