



---

# Reliability Outlook

An adequacy assessment of Ontario's  
electricity system

January 2024 to June 2025



# Executive Summary

Ontario's electricity grid is prepared for the next 18 months, with sufficient supply expected to be available to meet the needs of residents, businesses and communities. As we enter the winter 2023-24 season, sufficient reserves will be available throughout this period.

Looking ahead through the duration of this outlook, Ontario's electricity system is expected to remain adequate under normal weather conditions. To ensure reliability throughout summer 2024, the IESO will monitor for and work closely with market participants to schedule outages. To ensure reliability under extreme weather conditions in summer 2024, Ontario may have to consider relying on up to 2,000 MW of supply from other jurisdictions and/or additional operating actions, as it has in recent years.

Overall, Ontario has entered a period when generation and transmission outages are becoming more challenging to accommodate, and the IESO has been actively co-ordinating and planning with market participants to maintain reliability. While the reinforcement of scheduling of resource outages to date has improved reliability, the sheer volume of outage requests and the limited time periods available to complete the work will continue to make outage scheduling more challenging for the foreseeable future. Market participants are strongly encouraged to plan ahead and co-ordinate with the IESO to prepare the system and ensure planned outages can be appropriately scheduled.

Forecasted energy demand remains steady for this Reliability Outlook period, with a projected increase of 0.7 per cent for 2023, and 1.2 per cent for 2024. As energy demand is correlated with economic activity, these forecasts are based on expectations the cumulative impacts of interest rate changes and inflation readings have a lagged effect on economic growth. Additionally, the forecasted demand reflects the beginning of increased electrification from fuel-switching.

The 2023 Capacity Auction recently concluded, securing 1,867 MW and 1,311 MW of capacity for the 2024 summer and 2024-2025 winter obligation periods, respectively. The capacity cleared through this year's auction significantly exceeded the 1,431 MW and 1,160 MW that last year's auction cleared for the 2023 summer and 2023-2024 winter obligation periods, respectively, as the IESO continues to deliver capacity in response to changing needs in the system. Additionally, the Medium-Term RFP (MT RFP) announced last year will be realized in this Reliability Outlook's time horizon, during which supply from both existing gas and wind resources are expected to continue supporting reliability as a few of their contracts signed under MT RFP take effect in May 2024.

Refurbishment of Ontario's nuclear resources, in which up to four units are on outage at any one time, are ongoing. Outage schedules remain on track, and the IESO is confident it will maintain system reliability as refurbishment work continues at Bruce and Darlington nuclear generating stations.

<b>Executive Summary</b>	<b>1</b>
<b>1. Introduction</b>	<b>5</b>
<b>2. Updates to this Outlook</b>	<b>6</b>
2.1 Updates to the Demand Forecast	6
2.2 Updates to Resources	6
2.3 Updates to the Transmission Outlook	6
<b>3. Demand Forecast</b>	<b>7</b>
<b>4. Resource Adequacy</b>	<b>12</b>
4.1 Assessment Assumptions	13
4.1.1 Generation Resources	13
4.1.2 Generation Capability	15
4.1.3 Demand Measures	17
4.1.4 Firm Transactions	17
4.1.5 Summary of Scenario Assumptions	18
4.2 Capacity Adequacy Assessment	20
4.2.1 Firm Scenario with Normal and Extreme Weather	20
4.2.2 Planned Scenario with Normal and Extreme Weather	22
4.2.3 Comparison of the Current and Previous Weekly Adequacy Assessments for the Firm Extreme Weather Scenario	23
4.3 Energy Adequacy Assessment	24
4.3.1 Summary of Energy Adequacy Assumptions	24
4.3.2 Results – Firm Scenario with Normal Weather	24
4.3.3 Findings and Conclusions	25
<b>5. Transmission Reliability Assessment</b>	<b>27</b>
5.1 Transmission Projects	27

5.2	Transmission Outages	27
5.3	Transmission Considerations	27
<b>6.</b>	<b>Operability</b>	<b>31</b>
6.1	Outage Management Considerations	31
<b>7.</b>	<b>Resources Referenced in This Report</b>	<b>33</b>
<b>8.</b>	<b>List of Acronyms</b>	<b>34</b>

## List of Figures

<b>Figure 4-1   Monthly Wind Capacity Contribution Values .....</b>	<b>16</b>
<b>Figure 4-2   Monthly Solar Capacity Contribution Values .....</b>	<b>17</b>
<b>Figure 4-3   Comparison of Normal and Extreme Weather: Firm Scenario Reserve Above Requirement .....</b>	<b>21</b>
<b>Figure 4-4   Comparison of Normal and Extreme Weather: Planned Scenario Reserve Above Requirement .....</b>	<b>22</b>
<b>Figure 4-5   Comparison of Current and Previous Outlook: Firm Scenario Extreme Weather Reserve Above Requirement .....</b>	<b>23</b>
<b>Figure 4-6   Forecast Energy Production by Fuel Type.....</b>	<b>25</b>
<b>Figure 4-7   Forecast Monthly Energy Production by Fuel Type.....</b>	<b>26</b>

# List of Tables

<b>Table 3-1   Forecast Energy Demand Summary .....</b>	<b>7</b>
<b>Table 3-2   Forecast Seasonal Peaks .....</b>	<b>8</b>
<b>Table 3-3   Weekly Energy and Peak Demand Forecast .....</b>	<b>8</b>
<b>Table 4-1   Existing Grid-Connected Resource Capacity .....</b>	<b>13</b>
<b>Table 4-2   Committed Generation Resources Status.....</b>	<b>14</b>
<b>Table 4-3   Monthly Historical Hydroelectric Median Values for Normal Weather Conditions .....</b>	<b>15</b>
<b>Table 4-4   Summary of Available Resources under Normal Weather .....</b>	<b>19</b>
<b>Table 4-5   Summary of Zonal Energy for Firm Scenario Normal Weather .....</b>	<b>24</b>
<b>Table 4-6   Energy Production by Fuel Type for the Firm Scenario Normal Weather</b>	<b>26</b>
<b>Table 7-1   Additional Resources .....</b>	<b>33</b>



# 1. Introduction

This Outlook covers the 18 months from January 2024 to June 2025, and supersedes the Outlook released on September 21, 2023.

The purpose of the 18-month horizon in the *Reliability Outlook* is to:

- Advise market participants of the resource and transmission reliability of the Ontario electricity system
- Assess potentially adverse conditions that might be avoided by adjusting or coordinating maintenance plans for generation and transmission equipment
- Report on initiatives being implemented to improve reliability within this time frame

This Outlook assesses resource and transmission adequacy based on the stated assumptions, following the [Methodology to Perform the Reliability Outlook](#). Due to uncertainties associated with various assumptions, readers are encouraged to use their judgment in considering possible future scenarios.

Additional supporting documents are located on the [Reliability Outlook webpage](#).

[Security and adequacy assessments](#) are published on the IESO website on a daily basis and progressively supersede information presented in this report.

For questions or comments on this Outlook, please contact us at 905-403-6900 (toll-free 1-888-448-7777) or [customer.relations@ieso.ca](mailto:customer.relations@ieso.ca).



## 2. Updates to this Outlook

### 2.1 Updates to the Demand Forecast

The demand forecast used in this Outlook is informed by actual demand, weather and economic data through to the end of November 2023, and has been updated to reflect the most recent economic projections. Actual weather and demand data for October and November 2023 are included in the [tables](#).

### 2.2 Updates to Resources

This *Reliability Outlook* considers planned generator outages over the 18-month period, submitted by market participants to the IESO's outage management system as of November 27, 2023. Market participants are required annually to submit information to enable the IESO to conduct reliability assessments. This information, provided to the IESO through Form 1230, was submitted by April 1, 2023.

### 2.3 Updates to the Transmission Outlook

This Outlook also considers transmission outage plans that were submitted to the IESO's outage management system by October 31, 2023.

### 3. Demand Forecast

Electricity demand is expected to remain relatively flat at 137.7 TWh, a projected increase of 0.7% for 2023. This follows higher growth in each of the previous two years: 1.4% in 2021 (133.7 TWh) and 2.2% increase in 2022 (136.7 TWh). For 2024 demand is expected to increase to 139.3 TWh (1.2%). The IESO continues to monitor the evolving economic situation to assess the likely impacts to electricity demand over the 18-month horizon.

The IESO is responsible for forecasting electricity demand on the IESO-controlled grid. This demand forecast covers the period from January 2024 to June 2025 and supersedes the previous forecast released in September 2023. Tables of supporting information are contained in the [2023 Q4 Outlook Tables](#).

Electricity demand is very closely tied to economic activity. The Bank of Canada raised interest rates seven times in 2022 and three times in 2023, raising the overnight rate from 0.5% to 5.0%, in an effort to slow economic growth and reduce inflationary pressures. Economic data over the latter half of 2023 suggests that both of those two things are occurring. As those trends continue into 2024, economic and electricity demand growth will be muted over the front half of the year. As inflation falls into the Bank of Canada's target range, rate cuts combined with pent-up demand and population growth may accelerate economic and electricity growth over the latter half of 2024. With the aforementioned economic trajectory, energy demand is projected to increase by a modest 0.7% in 2023 and increase 1.2% in 2024 as building economic growth combines with the addition of large industrial loads and the beginning of increased electrification from fuel switching. The growth in 2024 is boosted by the additional leap day.

The demand forecast faces significant uncertainties. Interest rate impacts can lag significantly and carry a risk to economic growth. Geopolitical events contribute to uncertainty and instability should they spread to other countries.

**Table 3-1 | Forecast Energy Demand Summary**

Year	Normal Weather Energy (TWh)	% Growth in Energy
2023	137.7	0.75%
2024	139.3	1.19%



**Table 3-2 | Forecast Seasonal Peaks**

Season	Normal Weather Peak (MW)	Extreme Weather Peak (MW)
Winter 2023-24	21,418	22,657
Summer 2024	22,602	24,561
Winter 2024-25	21,523	22,759

**Table 3-3 | Weekly Energy and Peak Demand Forecast**

Week Ending	Normal Peak (MW)	Extreme Peak (MW)	Load Forecast Uncertainty (MW)	Normal Energy Demand (GWh)
07-Jan-24	20,600	21,628	528	2,814
14-Jan-24	21,094	22,125	570	2,914
21-Jan-24	21,169	22,214	547	2,937
28-Jan-24	21,418	22,657	483	2,955
04-Feb-24	21,360	22,433	404	2,931
11-Feb-24	20,988	21,857	734	2,894
18-Feb-24	20,539	21,704	635	2,893
25-Feb-24	20,321	21,812	581	2,846
03-Mar-24	20,261	21,787	501	2,835
10-Mar-24	19,645	21,115	531	2,767
17-Mar-24	19,131	20,666	649	2,723
24-Mar-24	18,584	20,058	611	2,657
31-Mar-24	18,109	19,260	569	2,557
07-Apr-24	17,854	18,756	567	2,531
14-Apr-24	17,747	18,261	471	2,516

<b>Week Ending</b>	<b>Normal Peak (MW)</b>	<b>Extreme Peak (MW)</b>	<b>Load Forecast Uncertainty (MW)</b>	<b>Normal Energy Demand (GWh)</b>
21-Apr-24	17,685	18,293	496	2,482
28-Apr-24	17,414	17,775	531	2,421
05-May-24	17,338	18,975	721	2,411
12-May-24	17,339	19,566	849	2,391
19-May-24	17,426	21,028	845	2,414
26-May-24	17,576	20,986	1,175	2,357
02-Jun-24	19,124	21,465	1,330	2,438
09-Jun-24	19,482	21,954	1,292	2,469
16-Jun-24	21,109	22,213	1,055	2,537
23-Jun-24	21,777	23,033	835	2,597
30-Jun-24	22,372	23,938	754	2,657
07-Jul-24	22,323	23,921	1,016	2,658
14-Jul-24	22,520	24,305	814	2,739
21-Jul-24	22,602	24,481	838	2,795
28-Jul-24	22,559	24,561	1,035	2,815
04-Aug-24	22,476	24,508	841	2,838
11-Aug-24	22,391	24,415	958	2,781
18-Aug-24	22,405	24,558	985	2,804
25-Aug-24	22,376	24,430	1,362	2,776
01-Sep-24	22,296	24,218	1,413	2,751
08-Sep-24	21,763	23,564	1,370	2,635
15-Sep-24	21,784	22,877	680	2,610
22-Sep-24	20,329	21,788	781	2,526

<b>Week Ending</b>	<b>Normal Peak (MW)</b>	<b>Extreme Peak (MW)</b>	<b>Load Forecast Uncertainty (MW)</b>	<b>Normal Energy Demand (GWh)</b>
29-Sep-24	18,794	21,076	420	2,496
06-Oct-24	17,866	19,487	554	2,469
13-Oct-24	17,581	18,615	786	2,463
20-Oct-24	17,506	18,026	507	2,432
27-Oct-24	17,756	19,037	392	2,508
03-Nov-24	17,915	19,381	318	2,538
10-Nov-24	18,473	19,830	416	2,574
17-Nov-24	19,085	19,538	601	2,636
24-Nov-24	19,762	20,135	342	2,716
01-Dec-24	19,982	20,745	607	2,766
08-Dec-24	20,435	21,270	409	2,820
15-Dec-24	20,601	21,764	555	2,849
22-Dec-24	20,687	21,825	690	2,885
29-Dec-24	18,579	20,142	362	2,693
05-Jan-25	19,963	20,853	528	2,812
12-Jan-25	21,245	22,309	570	2,934
19-Jan-25	21,272	22,347	547	2,952
26-Jan-25	21,523	22,759	483	2,970
02-Feb-25	21,478	22,534	404	2,962
09-Feb-25	21,091	21,955	734	2,909
16-Feb-25	20,641	21,824	635	2,908
23-Feb-25	20,445	21,917	581	2,861
02-Mar-25	20,373	21,954	501	2,860

<b>Week Ending</b>	<b>Normal Peak (MW)</b>	<b>Extreme Peak (MW)</b>	<b>Load Forecast Uncertainty (MW)</b>	<b>Normal Energy Demand (GWh)</b>
09-Mar-25	19,782	21,285	531	2,786
16-Mar-25	19,274	20,853	649	2,742
23-Mar-25	18,724	20,223	611	2,675
30-Mar-25	18,244	19,424	569	2,611
06-Apr-25	17,975	18,890	567	2,561
13-Apr-25	17,865	18,398	471	2,533
20-Apr-25	17,803	18,426	496	2,465
27-Apr-25	17,535	17,902	531	2,430
04-May-25	17,502	19,114	721	2,429
11-May-25	17,430	19,644	849	2,407
18-May-25	17,565	21,116	845	2,430
25-May-25	17,680	21,080	1,175	2,373
01-Jun-25	19,234	21,597	1,330	2,447
08-Jun-25	19,577	22,025	1,292	2,485
15-Jun-25	21,214	22,295	1,055	2,552
22-Jun-25	21,864	23,095	835	2,612
29-Jun-25	22,477	24,037	754	2,673
06-Jul-25	22,326	24,127	1,016	2,649

## 4. Resource Adequacy

Ontario's power system continues to operate in a period during which generation and transmission outages will be difficult to accommodate. The IESO expects these conditions to persist for the foreseeable future. Market participants are strongly encouraged to plan ahead and coordinate with the IESO to prepare the system and ensure planned outages can be appropriately scheduled.

The IESO expects to have sufficient reserves for the entirety of this outlook period under normal weather conditions. However, reserve shortages have the potential to appear in summer 2024 and 2025, primarily as a result of coincident generator outages. The IESO will work closely with market participants to schedule outages during this period, otherwise Ontario may have to rely on up to 2,000 MW of supply from other jurisdictions and/or additional operating actions to ensure reliability under extreme weather conditions.

This section assesses the adequacy of resources to meet the forecast demand. Resource adequacy is one of the reliability considerations used for approving generation and transmission outages. When reserves are below required levels, with potentially adverse effects on the reliability of the grid, the IESO will reject outage requests based on their order of precedence. Conversely, when reserves are above required levels, additional outages can be contemplated, provided other factors – such as local considerations, operability or transmission security – do not pose a reliability concern. In those cases, the IESO may place an outage at risk, signaling to the facility owner to consider rescheduling the outage.

Ontario's existing installed generation capacity is summarized in Table 4-1. The forecast capability at the Outlook peak is based on the firm resource scenario, which includes resources currently in commercial operation, and takes into account deratings, planned outages and an allowance for capability levels below rated installed capacity.

**Table 4-1 | Existing Grid-Connected Resource Capacity**

Fuel Type	Total Installed Capacity (MW)	Forecast Capability at 2024 Summer Peak Normal Weather (MW)	Forecast Capability at 2024 Summer Peak Extreme Weather (MW)	Number of Stations	Change in Number of Stations	Change in Installed Capacity
Nuclear	13,144	10,476	10,476	5	0	0
Hydroelectric	8,922	5,022	4,678	76	0	0
Gas/Oil	10,470	9,218	8,842	33	0	0
Wind	4,883	720	720	41	0	0
Biofuel	296	246	246	7	0	0
Solar	478	66	66	10	0	0
Demand Measures	-	1,591	1,591	-	-	-
Firm Imports (+) / Exports (-) (MW)	-	0	0	-	-	-
<b>Total</b>	<b>38,193</b>	<b>27,339</b>	<b>26,618</b>	<b>172</b>	<b>0</b>	<b>0</b>

## 4.1 Assessment Assumptions

### 4.1.1 Generation Resources

All generation resources scheduled to come into service, be upgraded or be shut down within the Outlook period are summarized in Table 4-2. This includes generation projects in the IESO's connection assessment and approval (CAA) process, those under construction, and contracted resources. Details regarding the IESO's CAA process and the status of these projects can be found on the [Application Status](#) section of the IESO website.

The estimated effective date column in Table 4-2 indicates when the market registration process is expected to be complete for each generation resource, based on information available to the IESO as of November 27, 2023. Two scenarios are used to describe project risks:

- The **planned scenario** assumes that all resources scheduled to come into service are available over the assessment period.
- The **firm scenario** assumes that only resources that have reached commercial operation status and completed commissioning at the time this assessment was completed are available.

Planned shutdowns or permanent<sup>1</sup> retirements of generators that have a high likelihood of occurring are considered for both scenarios.

**Table 4-2 | Committed Generation Resources Status**

Project Name	Zone	Fuel Type	Estimated Effective Date	Project Status	Firm Planned (MW)(MW)	
Romney Wind West Energy Center		Wind		Commercial Operation	0	60
Oneida Storage	Southwest	Storage	2025-Q2	Under Development	0	235
Total					0	295

**Notes on Table 4-2:**

The total may not add up due to rounding and does not include in-service facilities. Project status provides an indication of the project progress, using the following terminology:

- Under Development – projects in approvals and permitting stages (e.g., environmental assessment, municipal approvals, IESO connection assessment approvals) and projects under construction
- Commissioning – projects undergoing commissioning tests with the IESO
- Commercial Operation – projects that have achieved commercial operation status under the contract criteria, but have not met all of the IESO’s market registration requirements
- Expiring Contract – contracts that will expire during the Outlook period are included in both scenarios only up to their contract expiry date. Generators (including non-utility generators) that continue to provide forecast output data are also included in the planned scenario for the rest of the 18-month period.

<sup>1</sup> Given the evolving nature of resource acquisitions and commitments in Ontario, Table 4-2 will be listing new resources as they commission and existing resources that are expected to permanently retire or mothball at the end of their current commitments.

### 4.1.2 Generation Capability

#### Hydroelectric

A monthly forecast of hydroelectric generation output is calculated based on median historical values of hydroelectric production and contribution to operating reserve during weekday peak demand hours. Through this method, routine maintenance and actual forced outages of the generating units are implicitly accounted for in the historical data (see the first row in Table 4-3).

To reflect the impact of hydroelectric outages on the reserve above requirement (RAR) and allow the assessment of hydroelectric outages as per the outage approval criteria, the hydroelectric capability is also calculated, without accounting for historical outages (see the second row of Table 4-3). Table 4-3 uses data from May 2002 to March 2023 which are updated annually to coincide with the release of the Q2 Outlook.

**Table 4-3 | Monthly Historical Hydroelectric Median Values for Normal Weather Conditions**

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Historical Hydroelectric Median Contribution (MW)	6,167	6,090	5,910	5,927	5,958	5,769	5,604	5,306	5,087	5,453	5,708	6,162
Historical Hydroelectric Median Contribution without Outages (MW)	6,670	6,673	6,434	6,444	6,404	6,274	6,142	5,894	5,945	6,266	6,488	6,679

#### Thermal Generators


Thermal generators' capacity, planned outages and deratings are based on market participant submissions. Forced outage rates on demand are calculated by the IESO based on actual operational data. The IESO will continue to rely on market participant-submitted forced outage rates for comparison purposes.



Wind

For wind generation, monthly wind capacity contribution (WCC) values from the weekday peak hour are used. The process for determining wind contribution can be found in the [Methodology to Perform the Reliability Outlook](#). Figure 4-1 shows the monthly WCC values, which are updated annually with the release of the Q2 Outlook.


Figure 4-1 | Monthly Wind Capacity Contribution Values



Solar

For solar generation, monthly solar capacity contribution (SCC) values from the weekday peak hour are used. Information on how the solar contribution is calculated can be found in the [Methodology to Perform the Reliability Outlook](#). Figure 4-2 shows the monthly SCC values, which are updated annually for the release of the Q2 Outlook.

**Figure 4-2 | Monthly Solar Capacity Contribution Values**



#### 4.1.3 Demand Measures

Both demand measures and load modifiers can impact demand, but differ in how they are treated within the Outlook. Demand measures, such as dispatchable loads and demand response procured through the IESO's [capacity auction](#), are not incorporated into the demand forecast and are instead treated as resources. Load modifiers are incorporated into the demand forecast. The impacts of activated demand measures are added back into the demand history prior to forecasting demand for future periods.

#### 4.1.4 Firm Transactions

##### Capacity-Backed Exports

The IESO allows Ontario resources to compete in the capacity auctions held by certain neighbouring jurisdictions, but only if Ontario has adequate supply. New York Independent System Operator (NYISO)<sup>2</sup> will allow up to 80 MW of capacity-backed exports from Ontario between November 2023 and April 2024.

---

<sup>2</sup> [http://icap.nyiso.com/ucap/public/rgt\\_availability\\_display.do](http://icap.nyiso.com/ucap/public/rgt_availability_display.do)

## System-Backed Exports

The electricity trade agreement between Ontario and Quebec has expired as of March 2023, ending the supply of 500 MW of capacity to Quebec for winter months. However, Ontario will continue to receive up to 2.3 TWh of clean energy annually until December 31, 2023, scheduled economically via Ontario's real-time markets. The economically imported energy will target peak hours to help reduce greenhouse gas emissions in Ontario. The agreement includes the opportunity to cycle energy.

## Capacity Sharing Agreement

A 2015 Capacity Sharing Agreement with Hydro-Québec saw Ontario provide 500 MW of capacity to Québec in the winter of 2015/16. Ontario currently has a commitment from Québec to return 500 MW of firm capacity for four months during a summer of the IESO's choosing.

In August 2023, the governments of Ontario and Québec entered into a memorandum of understanding (MOU)<sup>3</sup> between the IESO and Hydro-Québec for the swap of 600 MW of capacity over a period of up to 10 years, expected to start in winter 2024/2025. Under this trade agreement, the IESO and Hydro-Québec will carry out an annual capacity swap of 600 MW. The IESO will provide 600 MW to Hydro-Québec in the winter and Hydro-Québec will provide 600 MW to the IESO in the summer. Ontario, will have the opportunity to bank any amount of the 600 MW of summer capacity provided each year for use in any future summer period during the agreement up to the 1250 MW capacity limit of the main Ontario-Quebec intertie, allowing the province to save capacity until it is required. More information can be found in the [2023 Capacity Sharing Agreement Backgrounder](#). Please note that this agreement is already considered when determining the 2,000 MW adequacy threshold.

### 4.1.5 Summary of Scenario Assumptions

To assess future resource adequacy, the IESO must make assumptions about the amount of available resources. The Outlook considers two scenarios: a firm scenario and a planned scenario.

The starting point for both scenarios is the existing installed resources shown in Table 4-1. The planned scenario assumes that all resources scheduled to come into service are available over the assessment period. The firm scenario considers only those resources that have reached commercial operation status as of the time of this assessment. Generator-planned shutdowns or retirements that have a high likelihood of occurring are considered for both scenarios. They also both reflect planned outages submitted by generators. Table 4-4 shows the available resources that are forecast over the 18-month Outlook, under both scenarios in normal weather conditions, and at the time of the summer and winter peak demands.

---

<sup>3</sup> <https://news.ontario.ca/en/release/1003444/the-governments-of-ontario-and-quebec-support-new-electricity-trade-agreement>

**Table 4-4 | Summary of Available Resources under Normal Weather**

Notes	Description	Winter Peak 2023/2024	Winter Peak 2023/2024	Summer Peak 2024	Summer Peak 2024	Winter Peak 2024/2025	Winter Peak 2024/2025
		Firm Scenario	Planned Scenario	Firm Scenario	Planned Scenario	Firm Scenario	Planned Scenario
1	Installed Resources (MW)	38,193	38,193	38,193	38,253	38,193	38,253
2	Total Reductions in Resources (MW)	12,333	12,293	12,462	12,513	12,435	12,250
3	Demand Measures (MW)	847	847	1,591	1,591	1,061	1,061
4	Firm Imports (+) / Exports (-) (MW)	-62	-62	0	0	-600	-600
5	Available Resources (MW)	26,645	26,685	27,322	27,331	26,219	26,464
6	Bottling (MW)	1,556	1,556	17	57	349	349
7	Available Resources without Bottling (MW)	28,201	28,241	27,339	27,388	26,569	26,814

**Notes on Table 4-4:**

1. Installed Resources: The total generation capacity assumed to be installed at the time of the summer and winter peaks.
2. Total Reductions in Resources: The sum of deratings, planned outages, limitations due to transmission constraints and allowances for capability levels below rated installed capacity.
3. Demand Measures: The amount of demand reduction expected to be available at the time of peak.
4. Firm Imports/Exports: The amount of expected firm imports and exports at the time of summer and winter peaks.
5. Available Resources: Installed Resources (line 1) minus Total Reductions in Resources (line 2) plus Demand Measures (line 3) and Firm Imports/Exports (line 4). This differs from the Forecast Capability at System Peak shown in Table 4-1 due to the impacts of generation bottling (transmission limitations).
6. Available Resources without Bottling: Available resources after they are reduced due to bottling.

## 4.2 Capacity Adequacy Assessment

The capacity adequacy assessment accounts for zonal transmission constraints resulting from planned transmission outages assessed as of October 31, 2023. The generation planned outages occurring during this Outlook period have been assessed as of November 27, 2023.

### 4.2.1 Firm Scenario with Normal and Extreme Weather

The firm scenario incorporates all capacity that had achieved commercial operation status as of November 27, 2023.

Figure 4-3 shows Reserve Above Requirement (RAR) levels, which represents the difference between available resources and required resources. The required resources equals forecast demand plus the required reserve.

Capacity secured in the December 2022 Capacity Auction (CA) has been included in this assessment. The target capacity for the December 2023 Capacity Auction, as announced in the IESO's [Resource Adequacy Update](#), have been included and modelled as demand measures in the firm resource scenario for summer 2024 and winter 2024/25<sup>4</sup>. Despite results not being available at the time of the assessment, the IESO secured 1,867 megawatts (MW) of supply for summer 2024 and 1,310 MW for winter 2024-2025 through its 2023 Capacity Auction, exceeding expectations performed in the assessment.

The IESO expects to have sufficient reserves for the winters of 2023/24 and 2024/25. In the firm scenario under extreme weather conditions, the reserve drops below 0 MW for 15 weeks in the summer of 2024, and for three weeks in the summer of 2025, but does not cross the adequacy threshold at any time.


The IESO has been carefully managing outages with participants to minimize impacts to the RAR adequacy threshold and has successfully navigated the summer of 2023. Moving forward, the IESO will continue to work closely with participants that have planned outages to ensure Ontario maintains adequate reserves. However, Ontario may have to rely on up to 2,000 MW of supply from other jurisdictions and/or additional operating actions in order to ensure reliability under extreme weather conditions.

Under periods of tighter supply conditions, planned generator maintenance outages are difficult to schedule. Generators are advised not to schedule outages during periods when reserves are forecast to be low, and are strongly encouraged to plan ahead and coordinate the timing of outages with IESO staff.

---

<sup>4</sup> Results of the December 2023 Capacity Auction were not available at the time this assessment was completed. This assessment has assumed that the Capacity Auction secured the targeted amounts, 1,400 MW for the summer of 2024 and 850 MW for the winter of 2024/25. Actual Capacity Auction results can be found in the post-auction report on the [IESO's webpage](#), and will be included in the firm scenario in future outlooks.

**Figure 4-3 | Comparison of Normal and Extreme Weather: Firm Scenario Reserve Above Requirement**




#### 4.2.2 Planned Scenario with Normal and Extreme Weather

The Planned scenario incorporates all existing capacity, as well as all capacity expected to come into service. Approximately 295 MW of new generation capacity is expected to connect to Ontario's grid over this Outlook period.

Figure 4-4 shows RAR levels under the Planned scenario. Reserves do not fall below the adequacy threshold requirements in this outlook period under normal or extreme weather conditions.


**Figure 4-4 | Comparison of Normal and Extreme Weather: Planned Scenario Reserve Above Requirement**



### 4.2.3 Comparison of the Current and Previous Weekly Adequacy Assessments for the Firm Extreme Weather Scenario

Figure 4-5 compares forecast RAR values in the current Outlook with those in the previous Outlook, which was published on September 21, 2023. The difference is primarily the result of an increase across the board on demand response measures as a result of making the AAR targets effective MW instead of installed MW. This becomes apparent around May 2024 at around 400 MW.

**Figure 4-5 | Comparison of Current and Previous Outlook: Firm Scenario Extreme Weather Reserve Above Requirement**



Resource adequacy assumptions and risks are discussed in detail in the [Methodology to Perform the Reliability Outlook](#).



## 4.3 Energy Adequacy Assessment

This section assesses energy adequacy to determine whether Ontario has sufficient supply to meet its forecast energy demands, while highlighting potential adequacy concerns during the Outlook time frame. At the same time, the assessment estimates the aggregate production by resource category to meet the projected demand based on assumed resource availability.

### 4.3.1 Summary of Energy Adequacy Assumptions

The energy adequacy assessment (EAA) uses the same set of assumptions as the capacity assessment outlined in Tables 4-1 and 4-2, which indicate the total capacity of committed resources and when they are expected to be available over the next 18 months. The monthly forecast of energy production capability, based on energy modelling results, is included in the [Reliability Outlook Tables](#).

For the EAA, only the firm scenario in Table 4-5 with normal weather demand is assessed. The key assumptions specific to this assessment are described in the [Methodology to Perform the Reliability Outlook](#).

### 4.3.2 Results – Firm Scenario with Normal Weather

Table 4-5 summarizes the energy simulation results over the next 18 months for the Firm scenario with normal weather demand both for Ontario and for each transmission zone.

**Table 4-5 | Summary of Zonal Energy for Firm Scenario Normal Weather**

Zone	18-Month Energy Demand TWh	18-Month Energy Demand Average MW	18-Month Energy Production TWh	18-Month Energy Production Average MW	Net Inter- Zonal Energy Transfer TWh	Zonal Energy	
						Demand on Peak Day of 18- Month Period GWh	Available Energy on Peak Day of 18Month Period GWh
Bruce	1.1	83	63.9	4,868	62.8	1.5	137.6
East	13.1	996	17.6	1,338	4.5	26.3	105.1
Essa	13.9	1,059	3.8	286	-10.1	29.9	16.2
Niagara	6.4	489	21.0	1,600	14.6	14.8	48.3
Northeast	16.0	1,218	15.8	1,203	-0.2	26.7	38.6
Northwest	5.6	426	6.7	513	1.1	9.4	18.6
Ottawa	13.1	998	0.7	52	-12.4	29.7	1.8
Southwest	42.4	3,229	8.3	628	-34.1	95.1	23.6

Zone	18-Month Energy Demand TWh	18-Month Energy Demand Average MW	18-Month Energy Production TWh	18-Month Energy Production Average MW	Net Inter- Zonal Energy Transfer TWh	Zonal Energy	Available Energy on Peak Day of 18Month Period GWh
						Demand on Peak Day of 18- Month Period GWh	
Toronto	75.0	5,712	54.5	4,153	-20.5	171.8	149.6
West	21.9	1,670	16.3	1,241	-5.6	51.8	80.0
<b>Ontario</b>	<b>208.5</b>	<b>15,881</b>	<b>208.5</b>	<b>15,882</b>	<b>0.0</b>	<b>457.0</b>	<b>619.3</b>


### 4.3.3 Findings and Conclusions

The EAA indicates that Ontario is expected to have sufficient supply to meet its forecast energy needs throughout the outlook period for the Firm scenario with normal weather demand, without having to rely on support from external jurisdictions.


The figures and tables in this section are based on a simulation of the province's power system, using the assumptions presented within the Outlook to assess whether Ontario will be energy adequate.

Figure 4-6 breaks down projected production by fuel type to meet Ontario's energy demand for the next 18 months, while Figure 4-7 shows the expected production by fuel type for each month. The province's energy exports and imports are not considered in this assessment. Table 4-6 summarizes these simulated production results by fuel type, for each year.

**Figure 4-6 | Forecast Energy Production by Fuel Type**



**Figure 4-7 | Forecast Monthly Energy Production by Fuel Type**



**Table 4-6 | Energy Production by Fuel Type for the Firm Scenario Normal Weather**

Fuel Type (Grid-Connected)	2024 (Jan 1 – Dec 31) (GWh)	2025 (Jan 1 – June 30) (GWh)	Total (GWh)
Nuclear	78,774	35,598	114,371
Hydro	36,780	19,394	56,174
Gas & Oil	12,652	7,585	20,238
Wind	10,290	5,870	16,160
Biofuel	363	147	509
Other (Solar & DR)	687	354	1,040
<b>Total</b>	<b>139,546</b>	<b>68,947</b>	<b>208,493</b>

## 5. Transmission Reliability Assessment

Ontario's transmission system is expected to continue to reliably supply province-wide demand for the next 18 months, even while experiencing normal contingencies defined by planning criteria. However, some combinations of transmission and/or generation outages could create operating challenges. For this reason, it is – and will continue to be – increasingly difficult to schedule certain outages to avoid reliability concerns. The volume of outage requests and the limited time periods available to complete the work will make outage scheduling a challenge for the foreseeable future.

The IESO assesses transmission adequacy using a methodology based on conformance to established criteria, including the [Ontario Resource and Transmission Assessment Criteria \(ORTAC\)](#), [NERC transmission planning standard TPL 001-4](#) and [NPCC Directory #1](#) as applicable. Planned system enhancements and projects and known transmission outages are also considered in the studies.

### 5.1 Transmission Projects

This section considers the information transmitters have provided with respect to transmission projects that are planned for completion within the next 18 months. The list of transmission projects can be found in [Appendix B1](#). Note that the planned in-service dates in this table and throughout this document are as of November 2023. These dates are subject to change as the COVID-19 pandemic may impact project logistics. Any changes will be communicated through subsequent Reliability Outlooks.

### 5.2 Transmission Outages

The IESO's assessment of transmission outage plans is shown in [Appendix C, Tables C1 to C11](#). The methodology used to assess the transmission outage plans is described in the [Methodology to Perform the Reliability Outlook](#). This Outlook reflects transmission outage plans submitted to the IESO as of October 31, 2023.

### 5.3 Transmission Considerations

The purpose of this section of the report is to highlight projects and outages that may affect reliability and/or the scheduling of other outages, and to consolidate these considerations by zone. For more information about the IESO's transmission zones and interfaces, please see the [Transfer Capability Assessment Methodology](#).

## **Bruce, Southwest, and West Zones**

Significant growth in the greenhouse sector has led to a number of customer connection requests in the Windsor-Essex region that are expected to exceed the capacity of the existing transmission system in the area. The new switching station ("Lakeshore TS") at the Leamington Junction has been installed and all four of the existing circuits have been cut over. The first South Middle Rd load station is connected by radial circuits to Lakeshore TS and new loads have begun connecting. Work is currently on-going for the second load station. The new Lakeshore RAS has been installed, and resulting operational measures available will be restrictive over the course of this period. During this time, system resiliency will be reduced, and per market rule exemptions in place, certain customers in the area may experience a lower level of reliability.

Multiple new transmission lines are under development in the region that will increase available supply starting mid-decade. Specifically, two new 230-kV circuits from Chatham SS to Lakeshore SS are expected to be in service in 2025 to support continued load growth.

The Bruce B 500 kV switchyard is being rebuilt and expected to be in-service by 2025 Q2. The existing circuits are being cut-over to the new switchyard, among other outages that are required. The following outages will impact the flow out of the Bruce zone:

The following outages will impact the flow out of the Bruce zone:

- A planned three-week outage starting November 13, 2023, on circuit B569B
- A planned five-week outage starting April 30, 2024, on circuit B501M
- A planned three-week outage starting April 1, 2024, on circuit B502M, and another planned two-week outage starting December 1, 2024
- A planned five-week outage starting August 26, 2024, on circuit B560V
- A planned three-week outage starting April 30, 2024, on circuit B561M

## **Toronto, East, and Ottawa Zones**

To address high voltages in eastern Ontario and the Greater Toronto Area, two 500 kV line connected shunt reactors have now been installed and are in-service at Lennox TS. There may continue to be a need to remove from service certain 500 kV circuits for voltage control during specific prevailing conditions.

There are upcoming nuclear refurbishments of multiple units at Darlington with overlapping timelines. As a result, it will be increasingly challenging for market participants to take outages impacting the Flow East Towards Toronto (FETT) interface. Future planned outages will necessitate enhanced coordination between transmitters and generators. Planned outages for certain windows may need to be rescheduled or rejected to ensure reliability. Of note, the FETT Capacity Upgrade (i.e., Richview-Trafalgar Reinforcement) project to address future needs is underway; the project is expected to be in-service by Q1 2026.

The two 230 kV circuits between Merivale TS and Hawthorne TS, a length of 12 km which supplies load in western Ottawa and delivers eastern Ontario resources, and imports from Quebec to other Ontario load centres, is being upgraded and expected to be in-service Q4 2023.

The following outages will impact the flow into Ottawa:

- A planned five-week outage starting September 8, 2024, on circuit T31H
- A planned three-week outage starting October 7, 2024, on circuit T32H

### **Northwest, Northeast, and Essa Zones**

The East-West Tie Expansion project consists of a new 230 kV transmission line roughly paralleling the existing East-West Tie Line between Wawa and Thunder Bay. The new line will increase the electricity transfer capability into Northwest Ontario and will improve the flexibility and efficiency of the Northwest electricity system. As part of this project, upgrades were planned for the Lakehead, Marathon and Wawa transformer stations to accommodate the new line. The project was placed in-service at the end of Q1 2022. However, the full benefit of the project will not be realized right away due to ongoing and upcoming outages as a result of work in the Northwest.

The following outages, all on circuit W21M, will reduce the transfer capability of the East-West tie:

- A two-week outage starting December 4, 2023
- A six-week outage starting April 8, 2024
- A five-week outage starting June 23, 2024
- A one-week outage starting November 4, 2024

In the Kirkland Lake area, a new RAS is planned to be in service in December 2023 that will enable load rejection, eliminating the need for pre-contingency load curtailment. In order to improve transmission system capacity, the Ansonville to Kirkland Lake A8K/A9K transmission circuits were refurbished and came in-service Q2 2023. Additional transmission refurbishments on Kirkland Lake to Matachewan are expected to be in-service by Q4 2024.

In the Sault Ste. Marie area, there will be an increase in load because of Algoma Steel converting their coke-fired furnaces to electric-arc furnaces over the next couple of years. The fluctuating nature of electric-arc furnace operation in an electrical area with limited transmission will require special attention to manage voltage and power fluctuations prior to the completion of the system reinforcements recommended in the Northeast Bulk System plan.

The “Barrie Area Transmission Upgrade” project is expected to come into service in Q4 2023. This project will convert the existing Barrie TS and its supply lines from Essa TS (circuits E3B and E4B) from 115 kV to 230 kV, enabling additional load to be supplied from Barrie TS. The existing 230/115 kV auto-transformers at Essa TS will no longer be needed after this conversion and will be retired.

The following outages will reduce the transfer capability of the North-South tie:

- A five-week outage on circuit X504E starting June 4, 2024
- A four-week outage on circuit X503E starting October 1, 2024

### **Interconnections**

The Phase Angle Regulators (PARs) between Ontario and New York have been replaced in order to provide greater flexibility to control intertie flows between Ontario and New York. The new PAR on L33P was put into service Q3 2022, and the PAR on L34P was replaced to match L33 P and is now in-service.

## 6. Operability

Ontario's power system is operating within a period of tighter supply conditions requiring careful consideration of outage management. The IESO will continue to assess other aspects of operability and report on them in future Outlooks where appropriate. This section highlights existing or emerging operability issues that could impact the reliability of Ontario's power system.

Operability refers to the IESO's ability to manage a variety of conditions on the power system as they occur in real-time. The IESO works to ensure that the power system is reliable under changing system conditions, variability of supply and fluctuations in load, while respecting thermal, voltage and transient stability limits on the system. Operability is assessed in advance to ensure that the power system is adequately prepared for expected real-time conditions, while also having the ability to absorb and adapt to unexpected changes.

### 6.1 Outage Management Considerations

Ontario continues to experience a period during which generation and transmission outages will be difficult to accommodate, and the IESO is working with market participants to manage this. In addition to meeting global Ontario adequacy needs, transmission adequacy and security must be safeguarded.

There are a significant number of major generation and transmission projects either currently underway or expected to begin in the near future. As the timing of many of these projects overlap with each other and can require multiple equipment outages, reliability assessments are increasingly complex. An example mentioned earlier describes major projects that are related to the Flow East Towards Toronto (FETT) interface.

With consideration of equipment failure, tighter supply conditions and other factors such as supply chain delays, some outages may need to be rejected and rescheduled. Transmitters and generators are strongly encouraged to plan ahead, coordinate with one another, submit outage requests early, and coordinate with the IESO; scheduling outages at desired times may still be difficult due to the significant number of major projects that are planned for the same time. Furthermore, outages are not guaranteed as unanticipated equipment failures may change reliability assessments.



One important aspect of grid equipment outages is recall time. Recall times indicate how long it takes for equipment on outage to return to service. Minimizing recall times increases the likelihood of outages being approved. If many outages are non-recallable, it can be difficult to accommodate additional outages as there needs to be a reliable plan to reposture the system after an equipment failure occurs on the grid. If multiple equipment failures occur, there may be instances where outage management alone will not address the concern. Under such circumstances the IESO may need to rely on additional non-firm imports or emergency operating procedures in order to ensure reliability. More information on actions the IESO can take to ensure reliability can be found in [Market Manual 7.1: IESO Controlled Grid Operating Procedures](#).

## 7. Resources Referenced in This Report

The table below lists additional resources in the order they appear in the report.

**Table 7-1 | Additional Resources**

Resource	URL	Location in This Report
Reliability Outlook Webpage	<a href="http://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Reliability-Outlook">http://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Reliability-Outlook</a>	Introduction
Security and Adequacy Assessments	<a href="http://www.ieso.ca/power-data/data-directory">http://www.ieso.ca/power-data/data-directory</a>	Introduction
2023 Q4 Outlook Tables	<a href="http://www.ieso.ca/-/media/files/ieso/document-library/planning-forecasts/reliability-outlook/ReliabilityOutlookTables_2023Dec.xls">http://www.ieso.ca/-/media/files/ieso/document-library/planning-forecasts/reliability-outlook/ReliabilityOutlookTables_2023Dec.xls</a>	Throughout
Connection Assessments and Approval Process	<a href="http://www.ieso.ca/en/sector-participants/connection-assessments/application-status">http://www.ieso.ca/en/sector-participants/connection-assessments/application-status</a>	Assessment Assumptions
Methodology to Perform the Reliability Outlook	<a href="http://www.ieso.ca/-/media/files/ieso/document-library/planning-forecasts/reliability-outlook/ReliabilityOutlookMethodology.pdf">http://www.ieso.ca/-/media/files/ieso/document-library/planning-forecasts/reliability-outlook/ReliabilityOutlookMethodology.pdf</a>	Throughout
Capacity Auction	<a href="http://www.ieso.ca/en/Sector-Participants/Market-Operations/Markets-and-Related-Programs/Capacity-Auction">http://www.ieso.ca/en/Sector-Participants/Market-Operations/Markets-and-Related-Programs/Capacity-Auction</a>	Demand Measures
Enabling Capacity Exports	<a href="http://www.ieso.ca/en/Sector-Participants/Market-Renewal/Capacity-Exports">http://www.ieso.ca/en/Sector-Participants/Market-Renewal/Capacity-Exports</a>	Firm Transactions
Ontario Resource and Transmission Assessment Criteria	<a href="https://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/connecting/IMO-REQ-0041-TransmissionAssessmentCriteria.ashx">https://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/connecting/IMO-REQ-0041-TransmissionAssessmentCriteria.ashx</a>	Transmission Considerations
NERC Transmission Planning Standard TPL-001-4	<a href="http://www.nerc.com/pa/Stand/Reliability%20Standards/TPL-001-4.pdf">http://www.nerc.com/pa/Stand/Reliability%20Standards/TPL-001-4.pdf</a>	Transmission Considerations
NPCC Directory #1	<a href="https://www.npcc.org/Standards/Directories/Directory_1_TFCP_rev_20151001_GJD.pdf">https://www.npcc.org/Standards/Directories/Directory_1_TFCP_rev_20151001_GJD.pdf</a> <a href="https://www.npcc.org/content/docs/public/program-areas/standards-and-criteria/regional-criteria/directories/directory-01-design-and-operation-of-the-bulk-power-system.pdf">https://www.npcc.org/content/docs/public/program-areas/standards-and-criteria/regional-criteria/directories/directory-01-design-and-operation-of-the-bulk-power-system.pdf</a>	Transmission Considerations
Market Manual 4 Part 4.2	<a href="http://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/market-operations/mo-dispatchdatartm.pdf?la=en">http://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/market-operations/mo-dispatchdatartm.pdf?la=en</a>	Surplus Baseload Generation
Market Manual 7.1	<a href="https://www.ieso.ca/en/sector-participants/market-operations/-/media/ccdae55168cc4ae8a4b73894ba305ebe.ashx">https://www.ieso.ca/en/sector-participants/market-operations/-/media/ccdae55168cc4ae8a4b73894ba305ebe.ashx</a>	Operability
Annual Acquisition Report	<a href="https://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Annual-Acquisition-Report">https://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Annual-Acquisition-Report</a>	Resource Adequacy

## 8. List of Acronyms

<b>Acronym</b>	<b>Definition</b>
CAA	Connection Assessment and Approval
DR	Demand Response
EAA	Energy Adequacy Assessment
FETT	Flow East Toward Toronto
GS	Generating Station
GTA	Greater Toronto Area
ICI	Industrial Conservation Initiative
IESO	Independent Electricity System Operator
IRRP	Integrated Regional Resource Plan
kV	Kilovolt
LDC	Local Distribution Company
MW	Megawatt(s)
NERC	North American Electric Reliability Corporation
NPCC	Northeast Power Coordinating Council
NYISO	New York Independent System Operator
ORTAC	Ontario Resource and Transmission Criteria
PAR	Phase Angle Regulator
RAR	Reserve Above Requirement
RAS	Remedial Action Scheme
SBG	Surplus Baseload Generation
SCC	Solar Capacity Contribution
TS	Transmission/Transformer Station
TWh	Terawatt-hour(s)
WCC	Wind Capacity Contribution

---

**Independent Electricity  
System Operator**

1600-120 Adelaide Street West  
Toronto, Ontario M5H 1T1

Phone: 905.403.6900

Toll-free: 1.888.448.7777

E-mail: [customer.relations@ieso.ca](mailto:customer.relations@ieso.ca)

**ieso.ca**



[@IESO\\_Tweets](https://twitter.com/IESO_Tweets)



[facebook.com/OntarioIESO](https://facebook.com/OntarioIESO)



[linkedin.com/company/IESO](https://linkedin.com/company/IESO)