

Feedback Form

Regional Electricity Planning in Windsor-Essex Area – December 12, 2023

Feedback Provided by:

Name: Ryan McLeod

Title: Director of Finance and Corporate Services

Organization: The Corporation of the Town of Kingsville

Email:

Date: January 5, 2024

To promote transparency, feedback submitted will be posted on the [Windsor-Essex engagement webpage](#) unless otherwise requested by the sender.

Following the Windsor-Essex electricity planning engagement webinar held on December 12, 2023, the Independent Electricity System Operator (IESO) is seeking feedback on the draft electricity demand forecast scenarios and Engagement Plan. A copy of the presentation as well as a recording of the session can be accessed from the [engagement web page](#).

Please submit feedback to engagement@ieso.ca by January 5, 2024.

Topic	Feedback
What additional information, if any, should be incorporated in the proposed electricity demand scenarios? How can	The Town has currently has approved and pending planning applications for over 1200 residential units on the west side of Kingsville (between Division Rd and McCain

Topic	Feedback
the proposed scenarios best capture the range and uncertainty of growth potential while informing near-term infrastructure investments?	<p>Side Rd). The Town is also expecting to expand its Sewage Treatment Facility in the next 5-7 years, which could increase its electrical demand by 30-40%. Sufficient electrical capacity will be required to meet housing and servicing demands.</p> <p>The greenhouse sector is anticipating 4,000 additional acres in the Leamington and Kingsville area by 2030. In addition to the direct electrical requirements, IESO should consider the electrical demands of the support industries for this sector. For example, the Union Water Treatment Plant is currently undergoing expansion plans increase water treatment capacity.</p>
What local issues and concerns should be considered in the electricity planning?	The Town of Kingsville currently experiences an unacceptable amount of electrical service disruptions, both in terms of frequency and duration. We understand this could be improved with an additional transmission line to our community. This infrastructure is critical to the future economic growth and sustainability of our municipality.
What information is important to provide to participants throughout this engagement?	Click or tap here to enter text.
Does the proposed Engagement Plan provide sufficient scope and opportunities for input?	Click or tap here to enter text.

General Comments/Feedback

Thank-you for the opportunity to provide feedback. If necessary, we are happy to provide additional information on the concerns noted above.